

# ADDENDUM NO. 1

COUNTY OF KAUA'I  
DEPARTMENT OF WATER

## INVITATION FOR BIDS

**GS-2025-02**

FOR THE  
FURNISHING AND DELIVERY  
OF

Two (2) 125KVA Trailer Mounted Emergency Generator and  
One (1) 220KVA Emergency Generator

### NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the INVITATION FOR BIDS and shall govern the work, taking precedence over previously issued plans and specifications governing the items mentioned for the subject project; and it shall amend the said contract documents in the following respects:

### ADDENDUM NO. 1

Questions and Answers.

### End of Addendum No. 1

Please submit questions for this solicitation at [www.publicpurchase.com](http://www.publicpurchase.com).

*Michael K. Hamazumi*

For: Joseph E. "Joe" Tait  
Chief Procurement Officer  
Manager and Chief Engineer  
October 1, 2024

### ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 1

Receipt Acknowledged:

\_\_\_\_\_  
Organization

\_\_\_\_\_  
Received by

\_\_\_\_\_  
Date

\_\_\_\_\_  
Title

**(ADDENDUMS MUST BE ACKNOWLEDGED AND INCLUDED WITH OFFER)**



# ADDENDUM NO. 1

**QUESTION NO. 1:** Will the County of Kauai accept bids that cite equipment that is not specified on the bid documents or not previously approved with an RFI?

ANSWER: Generator needs to meet the minimum requirements stated on our specifications sheet.