COUNTY OF KAUA'I DEPARTMENT OF WATER

PLANS, PROPOSAL, SPECIFICATIONS **CONTRACT AND BOND FOR**

JOB NO. 02-14, WK-08 KAPA'A HOMESTEADS 325' TANKS, TWO 0.5 MG TANKS, PACKAGE B - TANKS PACKAGE, KAPA'A, KAUA'I, HAWAI'I

NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

Item 1

Receipt of Questions/Comments/Material Substitutions.

End of Addendum No. 3

If there are any questions, please contact Jason Kagimoto by email at jkagimoto@kauaiwater.org.

Joseph E. "Joe" Tait Manager and Chief Engineer

March 23, 2023

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 3

Receipt Acknowledged:	
Organization	Received by
Date	Title
(Plea	se sign and return this acknowledgement.)

QUESTION 1: Please advise if any ground rings shall be added for the two new tanks to be constructed at the site as the electrical plans do not showcase this. Also, please advise if grounding shall be added to any metal piping or fencing for the new site and, if so, what sizing should this ground wire be.

Answer: A ground ring is not needed for the tanks. Grounding is not needed for the fence or metal piping.

QUESTION 2: Please see Drawing Page S-2, Note 8. Note 8 requests for a leakage test to be performed. Will water for the leakage test be provided by the Department or must the Contractor provide water for the leakage test?

Answer: Please refer to Section 2.5, Power and Water Supplies.

QUESTION 3: Spec Sections SP-11 11.03 C.d. "Conduits" and E.a.(1) "Conduits" specify the above ground conduit material type within the building line shall be rigid galvanized steel but there is no indication as to what conduit material shall be added within the vaults. Please advise if Rigid galvanized steel shall be used in the vaults or if PVC rigid galvanized steel shall be used instead.

Answer: PVC pipe can be used in the vaults.

QUESTION 4: Will there be a possibility of extending the laydown area? Could a small section of the area (the park) located across Ka'apuni road be used as a laydown, field office, or parking area?

Answer: Potential Offerors may coordinate with the County of Kaua'i, Department of Parks and Recreation to secure approval.

QUESTION 5: Drawing C-15 indicates Walls 1 & 2 are CRM however drawing S-16 indicates the walls are CMU. Please confirm which is correct.

Answer: Please follow the details on Sheet S-16.

QUESTION 6: Can the RFI deadline be extended?

Answer: The RFI deadline will not be extended.

QUESTION 7: Drawing E-3 indicates two ductbank runs tagged as Duct Section J and Duct Section K coming from the existing SCADA cabinet at the west side of Ornellas Tank. There is a third ductbank run above Duct Sections J and K turning to a pullbox and an existing SCADA pole in the Control Valve No. 2 & No. 3 location without a tag or Duct and Wire Schedule information. The same ductbank run exists on Drawing E-4 in Detail 2 south of Control Valve 2. Please clarify the proposed work to be completed at this run as it is shown to be new on drawing page E-3.

Answer: The conduit that is not labeled and the handhole to the existing Scada pole does not need to be provided.

QUESTION 8: Please see Act 17 Apprenticeship Form that was provided within the contract documents. In speaking with the unions, they have found that the form looks to be different from the standard format [They say the listing (4.1, 4.2, ... etc) is not the same as it would typically be]. They would like to know if this Act 17 Form is an acceptable form to be turned in with the bid.

Answer: Act 17 form is an acceptable form.

QUESTION 9: Drawing E-3 portrays liquid-tight flexible metal conduit extending from junction boxes in Tanks A and B to all Tank Hatch Security Switches "HS", typical of 12. Also on Drawing E-3, liquid-tight flexible metal conduit extends from junction boxes on the south end of Tank A and the east end of Tank B to Tank Stairs Security Alarm Switches "GS2" and "GS3". Detail 3 on Drawing E-7 and Detail 1 on Drawing E-8 indicate stainless steel armored cable instead of liquid-tight flexible metal conduit. Please confirm whether liquid-tight flexible metal conduit or armored cable is required.

Answer: Contractor shall use the stainless steel armored cable for the tank hatch security.

QUESTION 10: From Profile Views in Drawing C-12, the 16" DIP Washout Lines from Tanks A and B that are encased in concrete were specified as Class 53 then it changes to Class 52 once the pipes are not encased, but the 16" DIP Overflow Line from Tanks A and B that are encased in concrete were specified as Class 52 from Profile View in Drawing C-12 and remains Class 52 once the pipe is not encased; Drawing S-8 Detail 1 specified the encased 16" DIP Overflow Line as Class 53. Please clarify Class number (thickness) of the 16" DIP Washout Lines and Overflow Lines when it's encased in concrete and when it's not encased in concrete.

Answer: All concrete encased pipe must be Class 53. Class 52 is acceptable for non-concrete encased pipe.

QUESTION 11: Drawing C-20, Water Line "A", BL A, Station 2+82.42 indicates to use Concrete Block with Structural Struts but did not specify which Detail to use from the Structural Drawings. Please specify which detail to use.

Answer: Use Detail B shown on S-18.

QUESTION 12: Drawing C-9 Notes 5 and 6 both referenced Sheet C-30 for Concrete Block details but there's nothing shown in C-30 that's regarding Concrete Blocks. Please clarify which Sheet/Detail to use for Concrete Thrust Beam for Reducer and for Concrete Block with Structural Struts besides Sheets S-17 and S-18.

Answer: See Sheet C-29 for Typical Thrust Block with structural Struts for Connections and Concrete Trust Beam for Reducer.

QUESTION 13: Please confirm if all underground Gate Valves for the Water Lines are MJ and if they need Anchor Block as shown on Drawing C-29.

Answer: All gate valves must be provided with Gate Valve Anchor Block. Gate valves shall be push on or MJ unless otherwise called out on the drawings.

QUESTION 14: Please provide the manufacturer name of the existing RTU hardware and software being currently used at the site.

Answer: Schneider Electric SCADAPak32P and SCADAPak32 PLCs and Wonderware Software.

QUESTION 15: Based on Appendix B - General Provisions - Section 5.5 Differing Site Conditions, page 38, Contractor shall carry the cost and expense for any unknown conditions. This unknown cost to be carried in the bid will cause DOW to pay a significant amount due to Contractor's carrying additional money in their bids for work that may or may not actually happen for this unknown risk transferred to the Contractor. In order to minimize the cost that DOW will need to pay for unforeseen conditions that the Contractor is carrying in their bid and could end up not spending, please consider the below modification to the General Provisions as well as creating an allowance for this item as a "Contingency Allowance" so that DOW will only need to pay for actual cost for unforeseen conditions and any allowance not spent would be retuned to DOW in lieu of the Contactor seeing additional gains for this unused contingency in their bid.

Please see Appendix B - General Provisions - Section 5.5, Page 38. Please consider replacing the language in Section 5.5 Differing Site Conditions with the following:

"The CONTRACTOR shall promptly notify the DEPARTMENT of the following work site conditions (hereinafter called differing physical conditions), in writing, upon their discovery and before they are disturbed:

1. Subsurface or latent physical conditions differing from those indicated by information about the site made available to Bidders prior to the deadline for submitting bids; 2. Unknown physical conditions of any unusual nature, differing materially from those ordinarily encountered and generally recognized as inherent in work of the character being performed.

DEPARTMENT will promptly investigate conditions which appear to be differing physical conditions. If the DEPARTMENT determines that the conditions are differing physical conditions and will materially affect costs, a Change Order will be issued adjusting the compensation for such portion of the Work in accordance with General provision Section 5.3 Modifications To The Work. If the DEPARTMENT determines that conditions are differing physical conditions and they will materially affect performance time, the CONTRACTOR, upon submitting a written request, will be granted an extension of time subject to the provisions noted in General Provisions Section 5.3 Modifications To The Work and Section 8.3 Default, Delay, and Time Extensions."

Answer: Thank you for the suggestion. The Department of Water will consider this for future projects but will leave the referenced language in Appendix B as is for this project.

QUESTION 16: In Drawing C-17 from the List of Material for Control Valve Assembly 3 (6" Electronic Control Valve Detail), Item #8 indicates a 12"x6" reducer MJ with concrete thrust beam for reducer, but Call-out 8 in that detail can't be found. Please confirm that this 12"x6" reducer is the same item from C-09 Water Line C Station 0+12.72.

Answer: Confirming that the 12"x6" reducer is the same item from C-09 Water Line C Station 0+12.72.

QUESTION 17: In Drawing C-17 from the Control Valve Assemblies 2 and 3 details, there's a W1" arrow leading to the Control Valves. Please clarify where this line is coming from and what pipe material it is.

Answer: The W1" is copper pipe used to provide water from the 580 system to operate the ClaValves.

QUESTION 18: In Drawing C-17 from the List of Material for Temporary PRV Vault, Control Valve Assembly 2, and Control Assembly 3 details, hose bibbs were specified as 3/4", but from the Pressure Relief Valve Assembly for PRV Station detail in the same Drawing Sheet, hose bibb is specified as 1". Please clarify the size of Hose Bibbs.

Answer: On Sheet C-17 Pressure Relief Valve Assembly for PRV Station, replace 1" hose bibb with "3/4" hose bibb without check, threaded with cap (smooth nose) and 1" x 3/4" bushing".

QUESTION 19: Please clarify if there is a spare breaker or power source that can be utilized for temporary power for an office trailer.

Answer: Contractor to coordinate temporary power with KIUC for the officer trailer.

QUESTION 20: In Drawing C-17 from the Control Valve Assemblies 2 and 3 details, it calls out "Wall Sleeve (TYP) See Detail Sheet C-16" but in C-16 Wall Sleeve Detail, there's no Wall Sleeve shown in the detail. Please confirm if need Wall Sleeves or just patch with grout; and if Wall Sleeves are needed, please specify wall sleeve material.

Answer: Wall sleeve is not required. The pipe may be grouted in place at wall penetration.

QUESTION 21: Please specify where the Chlorination Box Detail in Drawing C-30 is for.

Answer: Chlorination box detail is not being used on this project.

QUESTION 22: In Drawing C-14, Profile View for Water Line E at Station 0+00, there's a pipe (about 10 ft long) leading from the 16" Cap to the 4" CO. Please specify what material is needed for the 4" pipe.

Answer: Use 4" Ductile Iron Pipe.

QUESTION 23: Please confirm if a field office is required to be provided for DOW or can an allowance be created to let the Department determine if one should be required or not after bidding. Answer: A field office is required as identified in SP-15.

QUESTION 24: Please provide pricing for the building permit required from the Department of Public Works mentioned in the Solicitation Documents - Section 2.3 Permits Page 18.

Answer: See Section SP-21 - Permits for information on Permits and fees.

QUESTION 25: In the water system standards 303.02 D.6 for yard finish material it states that Yard finishing material shall be lightly rolled to a smooth, even plane with suitable compaction as approved by the Manager. Please define suitable compaction.

Answer: Yard finishing material refers to topsoil for planting. Yard finishing material shall be lightly rolled to a smooth, even plane with suitable compaction, ready to receive planting.

QUESTION 26: In the water system standards 303.02 C.b it calls for side slopes to be 1.5:1 or otherwise noted in the drawings. Grading notes on C-1 note 5 it states "ALL SLOPES SHALL BE 2:1 OR FLATTER". Please confirm that all slopes are to be cut at 2:1 or flatter.

Answer: Slopes shall be 2:1 or flatter.

QUESTION 27: In the water system standards division 303.02 H.6 its states that required soil for fill, backfill, trench filling, etc shall be approved by manager. It doesn't reference a spec for the material. Please provide spec for fill material.

Answer: On-site material is suitable for trench backfill.

QUESTION 28: The Specification Section SP-12 12.03 B. "Programming" implies that the RTU supplier and Contractor are to supply a new RTU in addition to complete programming and documentation. In Drawing E-7, Detail 4 calls out "New cables to existing RTU". Please clarify if the Contractor is to supply a new RTU.

Answer: Specification Section SP-12.03 B only requires to provide the complete programming and documentation for the RTU. No new RTU to be installed.

QUESTION 29: Please clarify the existing SCADA integrator and possible integrators that are preferable or especially required for utilization.

Answer: The existing SCADA contractor is Glenmount Global Solutions.

QUESTION 30: In the job plans sheet C-11 it depicts a well on the NE side of the existing Tank. This well has a note that says "well by others" please specify if this work will be done before or after the scope of work for this project.

Answer: Well construction at the project site will be done after this project.

QUESTION 31: In the job plans sheet C-11 under Profile - Wall 2 it calls out sheet C-14 for details, please confirm that the correct sheet should be sheet C-15.

Answer: See Sheet S-16 for wall details.

QUESTION 32: Note 6 on Drawing No. S-1, states that "it is very common that hard rock cores exist within this type of soils. The hardness and extent of the rock core might vary significantly at different locations. Therefore, some difficult drilling conditions will likely be encountered at the Project Site and shall be expected." In order to minimize the cost for DOW from drillers assuming that all the drilling will be through hard rock, it is common to include a unit price item or allowance in the Offer Schedule for drilling obstructions with an assumed quantity so that DOW only pays for the cost of the actual impacts from obstructions and not the full amount of drilling. These unit price items are typically either on an hourly unit or a linear foot unit. Please add a unit price item or allowance for drilling obstruction encountered and an assumed quantity to provide a uniform basis for comparing bids and minimize the cost to DOW for this unknown risk.

Answer: No unit price item or allowance will be added for hard rock core drilling.

QUESTION 33: In Drawing C-16 from the Control Valve Assembly 1 Detail, Note 2 indicates that all flanged joints shall have silicon bronze bolts, but in Drawing C-17 from the Temporary PRV Vault Detail, Note 5 indicates that all fastening hardware shall be 316 Stainless Steel. The Water System Standards 2022 Section 202.01.F indicates that all bolts and nuts shall be either silicon bronze or 316 stainless steel. Please confirm if we really have to use different fastening materials for Control Valve Assembly 1 compared to the Temporary PRV; and please clarify which fastening material to use for Control Valve Assemblies 2 and 3 in Drawing C-17.

Answer: Bolts and nuts shall conform to Water System Standards 2002, Section 202.01.F.

QUESTION 34: Several key subcontractors have declined to bid due to another large project in Hawaii that is bidding on the same day. We respectfully request bid date to be moved to April 21, 2023.

Answer: Bid Opening date has been updated to April 28, 2023 (SEE ADDENDUM NO. 2).

QUESTION 35: Bid item 28 states in the last sentence to include "Concrete Caissons for two tanks, in place complete", however it appears that all the drilled shafts are accounted for in Bid Items 29-31. Please clarify what to include in bid item 28 for the concrete caissons.

Answer: For Item 28, delete, "Concrete Caissons for two tanks, in place complete." Concrete Caisson cost are included in Items 29, 30, and 31.

QUESTION 36: Please clarify what lengths the trial shafts will be and how much the test load will be. The production shafts have different load capacities so it's not clear what the test load should be. The proposed 75' test shaft is longer than the production shafts, which means the test shaft strength may not be indicative of the production pile strength.

Answer: See attached detail sheet and revised proposal form.

QUESTION 37: Please confirm that bidders should base their bids off only the hazardous/contaminated materials/soil that is shown or called out in the Contract Documents and anything discovered that is not shown will be handled per General Provisions 5.3.B and 5.4.

Answer: "If additional hazardous or contaminated material is encountered, the cost to handle the material will be per General Provisions 5.3.B and 5.4."

MATERIAL SUBSTITUTION REQUEST NO. 1: APPROVED (see attached)

Comment: Item No. 4, 1080 SY, 12" thick grass cell base, in place complete.


MATERIAL SUBSTITUTION REQUEST NO. 2: APPROVED (see attached)

Comment: Plan C-16 "Venturi Meter Differential Pressure Transmitter Hook-up and Mounting Schematic"

MATERIAL SUBSTITUTION REQUEST NO. 3: DENIED (see attached)

Comment: Horizonal access door information provided does not show double leaf access.

ADDENDUM NO. 3 Job No. 02-14, WK-08 Page 9



D User: HENRY File Created: April 23, 1998 File Last Updated: March 14, 2023 12:21:03pm : B:Drafting\Drafting\Completed47\5988-00&10Kapahi1.0MgStorageTanks\5988-00&10DrilledShaftLoadTestDetail.dwg\Model

	Contractor
	<u>OFFER</u>
	For
_	VATER, COUNTY OF KAUA'I, KAUA'I, HAWAI'I
	20
the undersigned Offeror, having familiarized itsel the performance of the contract and the cost of the specifications, "General Provisions for Construct Standards, 2002", Invitation For Bids, and other Construct within the time stipulated in the said documents, the performed, and to provide and furnish any and all utility and transportation services necessary to	on For Bids and other Contract Documents relating thereto, f with the terms of the contract, the local conditions affecting the work at the place where the work is done, the plans and tion Contracts of the Department of Water", "Water System Contract Documents, hereby proposes and agrees to perform, including all its component parts and everything required to all of the labor, materials, tools, expendable equipment, and to perform the contract, in a workmanlike manner, in place to in connection with these specifications and accompanying
· · ·	ESTEADS 325' TANKS, TWO 0.5 MG TANKS, CKAGE, KAPA'A, KAUA'I, HAWAI'I
on file in the office of the Department of Water for	or,
TOTAL SUM OFFER	DOLLARS
	(words)



(\$_____) said total sums being itemized on the following pages:

OFFER SCHEDULE

JOB NO. 02-14 WK-08, KAPA'A HOMESTEADS 325' TANKS, TWO 0.5 MG TANKS, PACKAGE B – TANKS PACKAGE, KAPA'A, KAUA'I, HAWAI'I

ITEM NO.	ESTIMATED QUANTITY	U/M	DESCRIPTION		UNIT PRICE	TOTAL
1	1	LS	Mobilization & Demobilization (Not to exceed 6% of the sum of all items excluding Lump Sum Offer of this item)			\$
2	540	CY	Site excavation, including clearing and grubbing, demolition, and hauling and disposal of excess material.	\$		\$
3	1,080	SY	Grass cell pavement, including top soil and seed, in place complete.	\$		\$
4	1,080	SY	12" thick grass cell base, in place complete.	\$		\$
5	12	LF	Entry concrete header, including 6" aggregate base course, in place complete.	\$		\$
6	800	LF	6"x8" concrete header, including 6" aggregate base course, in place complete.	\$		\$
7	240	SY	AC walkway including base course, in place complete.	\$		\$
8	175	LF	Guardrail along Kawaihau Road, in place complete.	\$		\$
9	700	SY	Cold plane existing AC pavement and resurface with 2-inch thick State Mix V, including replacement of striping and pavement markers, in place complete.	\$		\$
10	730	LF	6-foot high chain-link fence topped with extension arm and three strands of barbed wire, including DWS 2500 concrete footing and all appurtenances, in place complete.	\$		\$
11	1	EA	14-feet wide, double-swing 6-foot high chain-link gate topped with extension arm and three strands of barbed wire, including DWS 2500 concrete footing, sign, and all appurtenances, in place complete.	\$		\$
12	1	LS	CRM Wall 1, in place complete.			\$



ITEM NO.	ESTIMATED QUANTITY	U/M	DESCRIPTION		UNIT PRICE	TOTAL
13	1	LS	CMU Wall 2, in place complete.			\$
14	150	LF	18" Corrugated High-Density Polyethylene Drainline, including unclassified trench excavation, backfill, and all appurtenances, in place complete.	\$		\$
15	90	LF	12" Corrugated High-Density Polyethylene Drainline, including unclassified trench excavation, backfill, and all appurtenances, in place complete.	\$		\$
16	1	EA	County DPW standard drain inlet, Type G-4, 3.00'-3.99', including unclassified trench excavation and backfill, in place complete.	\$		\$
17	1	EA	County DPW standard drain inlet, Type G-4, 4.00'-4.99', including unclassified trench excavation and backfill, in place complete.	\$		\$
18	1	EA	County DPW standard drain inlet, Type G-4, 6.00'-6.99', including unclassified trench excavation and backfill, in place complete.	\$		\$
19	1	EA	County DPW standard drain manhole detail C-24 for pavement areas with grated cover, 6.00'-6.99' deep, including unclassified trench excavation and backfill, in place complete.	\$		\$
20	1	EA	County DPW standard drain manhole detail C-24 for pavement areas with grated cover, 7.00'-7.99' deep, including unclassified trench excavation and backfill, in place complete.	\$		\$
21	800	LF	16" Ductile Iron Pipe Waterline; Cl. 52, including unclassified trench excavation, backfill, and all appurtenances, in place complete.	\$		\$
22	860	LF	12" Ductile Iron Pipe Waterline; Cl. 52, including unclassified trench excavation, backfill, and all appurtenances, in place complete.	\$		\$



ITEM NO.	ESTIMATED QUANTITY	U/M	DESCRIPTION		UNIT PRICE		TOTAL
23	2	EA	1" Air/Vacuum Relief Valve including all appurtenances, in place complete.	\$		\$	
24	1	LS	Control Valve Assembly 1, including 6" combination back pressure and solenoid shutoff valve, universal venturi tube with stainless steel body and flange ends, differential pressure transmitter for venturi tube with copper and stainless steel tubings, shut off valves and cocks, stainless steel U-bolt and nuts and mounting bracket, fittings, valves, all appurtenances, control valve assembly boxes with access doors and gravel, excavation and backfill, in place complete.			\$	
25	1	LS	Control Valve Assembly 2, including 6" combination back pressure and solenoid shutoff valve, fittings, valves, all appurtenances, control valve assembly box with access doors and gravel, excavation and backfill, in place complete.			\$	
26	1	LS	Control Valve Assembly 3, including 6" altitude valve, fittings, valves, all appurtenances, control valve assembly box with access doors and gravel layer, excavation and backfill, in place complete.			\$	
27	1	LS	Temporary pressure reducing valve, including 4" pressure reducing valve, 2" bypass, fittings, valves, all appurtenances, valve box with access doors and gravel, excavation and backfill, in place complete.			\$	
28	2	EA	0.5 Million Gallon reinforced concrete reservoir tank, including all appurtenances, in place complete.Concrete Caissons for two tanks, in place complete.	\$		\$	
29	34	EA	Shaft Type A (43') – Interior	\$		\$	
30	8	EA	Shaft Type B (56') – Beneath columns	\$		\$	
31	36	EA	Shaft Type C (56') – Perimeter	\$		\$	



ITEM NO.	ESTIMATED QUANTITY	U/M	1 DESCRIPTION		UNIT PRICE	TOTAL
32	1	EA	Load Test	\$		\$
32a	1	EA	75 foot Test Shaft	\$		\$
33	2	EA	Tank stairway, including landings, handrails, doors, fencing, locks, and all appurtenances, in place complete.	\$		\$
34	2	EA	Tank level pressure transmitter, including 1-inch single service lateral connection, ball corp, joint coupling, ball stop, reducing bushing and adapters, tee with plug, other fittings, water level pressure transmitter, stainless steel post, base and anchor bolts, for a complete job.	\$		\$
35	540	LF	6-inch corrugated, perforated HDPE drain line, including unclassified trench excavation, backfill, and all appurtenances, in place complete.	\$		\$
36	1	LS	Connection of New 12" Ductile Iron Waterline to Existing 12" Asbestos- Cement Waterline at Baseline A Sta. 1+38 (o/s 41.83' RT), including all appurtenances, in place complete.			\$
37	1	LS	Connection of New 12" Ductile Iron Waterline to Existing 12" Asbestos- Cement Waterline at Baseline A Sta. 0+71.97 (o/s 22.06' RT), including all appurtenances, in place complete.			\$
38	1	LS	Connection of New 12" Ductile Iron Waterline to Existing 12" Asbestos- Cement Waterline at Baseline A Sta. 0+84.58 (o/s 43.64' RT), including all appurtenances, in place complete.			\$
39	1	LS	Connect to Existing 6" Waterline at Baseline A Sta. 2+77 (o/s 3.34' LT), including unclassified excavation, cut and plug, fittings, concrete block with structural strut, temporary cleanout, and all appurtenances, in place complete.			\$
40	1	LS	Connect to Existing 12" Waterline at WL A Sta. 4+50.07, including unclassified			\$



ITEM NO.	ESTIMATED QUANTITY	U/M	DESCRIPTION	UNIT PRICE	TOTAL
			excavation, fittings, couplings, concrete block with structural strut, valves and valve boxes, temporary cleanout, and all appurtenances, in place complete.		
41	1	LS	Connection of New 8" Ductile Iron Waterline to Existing 8" Cast Iron Waterline at WL B Sta. (-)0+31.51 (o/s 24.17' RT), including all appurtenances, in place complete.		\$
42	1	LS	Connection of New 12" Ductile Iron Waterline to Existing 12" Asbestos- Cement Waterline at WL C Sta. (-)1+71.38, including all appurtenances, in place complete.		\$
43	1	LS	Connection of New 12" Ductile Iron Waterline C to Existing 12" Ductile Iron Waterline at WL C Sta. (-)1+12.92, including all appurtenances, in place complete.		\$
44	1	LS	Connection of New 12" Ductile Iron Waterline F to Existing 12" Asbestos- Cement Waterline at WL F Sta. 1+73.39, including all appurtenances, in place complete.		\$
45	1	LS	Chlorination and flushing of water system, including removal of temporary risers and incidental work, all in accordance with the specifications.		\$
46	1	LS	Furnish and install electrical equipment and wiring, including but not limited to trenching and backfill, pullboxes, power, control and instrumentation ducts, cables, junction boxes, connections to power, control and instrumentation devices, painting, testing, and all appurtenant electrical work in place complete and in accordance with the plans and specifications.		\$
47	1	LS	SCADA system, including but not limited to software programming of existing RTU;		\$



ITEN NO	ESTIMATED QUANTITY	U/M	DESCRIPTION		UNIT PRICE	TOTAL
			modifications to existing master SCADA; and all appurtenant SCADA work; in place complete, and in accordance with the plans and specifications, ready for operation.			
			TOTAL PACKAGE B SUM OFFER (Items 1 to 47 inclusive)			\$



SCHEDULE B HAWAI'I PRODUCTS PREFERENCE

In accordance with HRS §103D-1002, the Hawai'i products preference is applicable to this solicitation. Hawai'i Products ("HP") are available for those items noted on Schedule B, below. The Hawai'i products list is available on the SPO webpage at www.spo.hawaii.gov/for-state-county-personnel/manual/procurement/solicitation/goods-services-construction/preferences/hawaii-product-preferences/ or go to the SPO Home page, click on "For Vendors" tab; click on Preferences, Hawai'i Product Preferences to view. Offeror transmitting a Hawai'i Product (HP) shall identify the HP on Schedule B-1.

Any person desiring a Hawai'i product preference shall have the product(s) certified and qualified if not currently on the Hawai'i products list, prior to the deadline for receipt of offer(s) specified in the procurement notice and solicitation. The responsibility for certification and qualification shall rest upon the person requesting the preference. Persons desiring to qualify their product(s) not currently on the Hawai'i product list shall complete form SPO-038, Certification for Hawai'i Product Preference and submit, via email to the Procurement Officer issuing the solicitation, and provide the solicitation number and title in the subject line, and include all additional information required by the Procurement Officer. For each product, one form shall be completed and transmitted (i.e. 3 products should have 3 separate forms completed). Form SPO-038 is available on the SPO webpage at http://hawaii.gov/spo under the 'Quicklinks' menu; click on 'Forms for Vendors, Contractors, and Service Providers'.

When a solicitation contains both HP and non-HP, then for the purpose of selecting the lowest bid or purchase price only, the price offered for a HP item shall be decreased by subtracting 10% for the class I or 15% for the class II HP items offered, respectively. The lowest total offer, taking the preference into consideration, shall be awarded the contract unless the offer provides for additional award criteria. The contract amount of any contract awarded, however, shall be the amount of the price offered, exclusive of the preferences.

Change in Availability of Hawai'i product. In the event of any change that materially alters the Offeror's ability to supply Hawai'i products, the Offeror shall notify the Procurement Officer in writing no later than five (5) working days from when the Offeror knows of the change and the parties shall enter into discussions for the purposes of revising the contract or terminating the contract for convenience.

The following is a list of products that the Department anticipates will be used in this particular project; however the list is not all inclusive and additional products may be qualified.

HAWAI'I PRODUCTS LIST

HP Description

Manufacturer/Supplier Class

Aggregates and Sand – Basalt, rock, cinder, limestone and coral

Aggregates – Recycled asphalt and concrete

Asphalt and paving materials

Cement and concrete products

Pre-cast concrete products

Signs-traffic, regulatory and construction



HP Description

Manufacturer/Supplier Class

Soil amendments, mulch, compost

Bidders intending to use or supply a Hawai'i Product must list the price and total cost of each item f.o.b. jobsite, unloaded, including applicable general excise tax and use tax on this form. Failure to designate a Hawai'i product will mean that the Bidder is offering a non-Hawai'i product and award, if made to the bidder, will be on the basis that the bidder will deliver or use a non-Hawai'i product.

The Bidder shall list only the Manufacturers/Suppliers certified and qualified on Schedule B.

If the Department has awarded a contract under HRS, § 103D-1002, finds that in the performance of that contract there has been a failure to comply with HRS, § 103D-1002, the contract shall be voidable and the findings shall be referred for debarment or suspension proceedings under HRS 103D-702. Any purchase made or any contract awarded or executed in violation of this section shall be void and no payment shall be made by the Department on account of the purchase or contract.



SCHEDULE B-1 SCHEDULE OF MATERIAL COST

(if Hawai'i preference requested)

HAWAI'I			APPROX.		TOTAL COST OF
PRODUCT	MANUFACTURER	CLASS	QUANTITY	UNIT	MATERIAL
Aggregates and					
Sand – Basalt,					
rock, cinder,					
limestone and					
coral					
Aggregates –					
Recycled					
asphalt and					
concrete					
Asphalt and					
paving					
materials					
Cement and					
concrete					
products					
Pre-cast					
concrete					
products					
Signs-traffic,					
regulatory and					
construction					
Soil					
amendments,					
mulch, compost					



SCHEDULE C MANDATORY LICENSING REQUIREMENT

"A" general engineering contractors and "B" general building contractors are reminded that due to the Hawai'i Supreme Court's January 28, 2002 decision in Okada Trucking Co., Ltd. V. Board of Water Supply, et al., 97 Haw. 450 (2002), they are prohibited from undertaking any work, solely or as part of a larger project, that would require the general contractor to act as a specialty contractor in any area in which the general contractor has no license. Although the "A" and "B" contractor may still submit an offer on and act as the "prime" contractor on an "A" and "B" project (See, HRS § 444-7 for the definitions of an "A" and "B" project.), respectively, the "A" and "B" contractor may only perform work in the areas in which they have the appropriate "C" specialty contractor's license (An "A" or "B" contractor obtains "C" specialty contractor's licenses either on its own, or automatically under HAR § 16-77-32.). The remaining work must be subcontracted out to appropriately licensed "C" specialty contractors. It is the sole responsibility of the contractor to review the requirements of this project and determine the appropriate licenses that are required to complete the project.

LISTING OF SUBCONTRACTORS

Sec. 103D-302, H.R.S., provides that each offer for Public Works Construction Contracts shall include the name of each person or firm to be engaged by the Offeror as a joint contractor or subcontractor in the performance of the Public Works Construction Contract. The Offer shall also indicate the nature and scope of the work to be performed by such joint contractors or subcontractors. All offers which do not comply with this requirement shall be rejected pursuant to Sec. 103D-302(b) H.R.S.

To comply with the above provisions, the offeror shall complete the schedule of the nature and scope of work by listing, where applicable, the names of the joint contractors and subcontractors to be used after the description of the nature and scope of the work.

ALL JOINT CONTRACTORS OR SUBCONTRACTORS TO BE ENGAGED ON THIS PROJECT

The Offeror certifies that the following is a complete listing of all joint contractors and/or subcontractors who will be engaged by the Offeror on this Project to perform the nature and scope of work indicated regardless of the percentage of the value of the work to be performed by the joint contractor or subcontractor, pursuant to Section 103D-302, Hawai'i Revised Statutes, and understands that failure to comply with this requirement shall be just cause for rejection of the Offer.

The Offeror further understands that only those joint contractors or subcontractors listed shall be allowed to perform work on this Project. If no joint contractor or subcontractor for any subdivision of work is listed, it shall be construed that the work shall be performed by the Offeror with Offeror's employees.

All Offerors must be sure that they possess, and that the joint contractors or subcontractors listed in the Offer possess, all the necessary specialty licenses needed to perform the work for this Project. The Offeror shall be solely responsible for assuring that all specialty licenses required to perform the work is covered in the Offer.

The Offeror shall include the license number of the joint contractors or subcontractors listed below. Failure to provide the correct names and license numbers as registered with the Contractors Licensing Board may cause rejection of the offer submitted.

It is the <u>sole responsibility of the contractor</u> to review the requirements of this Project and determine the appropriate licenses that are required to complete the Project.



LISTING OF ALL JOINT CONTRACTORS OR SUBCONTRACTORS

	Contractor Classification	Name of Joint Contractor or Subcontractor	License Number
C-1	Acoustical and Insulation Contractor		
C-2	Mechanical Insulation Contractor		
C-3	Asphalt Paving and Surfacing Contractor		
C-3a	Asphalt Concrete Patching, Sealing, and Striping Contractor		
C-3b	Play Court Surfacing Contractor		
C-4	Boiler, Hot-Water Heating and Steam Fitting Contractor		
C-5	Cabinet, Millwork, and Carpentry Remodeling and Repairs Contractor		
C-5a	Garage Door and Window Shutters Contractor		
C-5b	Siding Application Contractor		
C-6	Carpentry Framing Contractor		
C-7	Carpet Laying Contractor		
C-9	Cesspool Contractor		
C-10	Scaffolding Contractor		
C-12	Drywall Contractor		
C-13	Electrical Contractor		
C-14	Sign Contractor		
C-15	Electronic Systems Contractor		
C-15a	Fire and Burglar Alarm Contractor		
C-15b	Telecommunications Contractor		
C-16	Elevator Contractor		
C-16a	Conveyor Systems Contractor		
C-17	Excavating, Grading, and Trenching Contractor		
C-19	Asbestos Contractor		
C-20	Fire Protection Contractor		
C-20a	Fire Repressant Systems Contractor		



	Contractor Classification	Name of Joint Contractor or Subcontractor	License Number
C-21	Flooring Contractor		
C-22	Glazing and Tinting Contractor		
C-22a	Glass Tinting Contractor		
C-23	Gunite Contractor		
C-24	Building Moving and Wrecking Contractor		
C-25	Institutional and Commercial Equipment Contractor		
C-27	Landscaping Contractor		
C-27a	Hydro Mulching Contractor		
C-27b	Tree Trimming and Removal Contractor		
C-31	Masonry Contractor		
C-31a	Cement Concrete Contractor		
C-31b	Stone Masonry Contractor		
C-31c	Refractory Contractor		
C-31d	Tuckpointing and Caulking Contractor		
C-31e	Concrete Cutting, Drilling, Sawing, Coring, and Pressure Grouting Contractor		
C-32	Ornamental, Guardrail, and Fencing Contractor		
C-32a	Wood and Vinyl Fencing Contractor		
C-33	Painting and Decorating Contractor		
C-33a	Wall Coverings Contractor		
C-33b	Taping Contractor		
C-33c	Surface Treatment Contractor		
C-34	Soil Stabilization Contractor		
C-35	Pile Driving, Pile and Caisson Drilling, and Foundation Contractor		
C-36	Plastering Contractor		
C-36a	Lathing Contractor		
C-37	Plumbing Contractor		



	Contractor Classification	Name of Joint Contractor or Subcontractor	License Number
C-37a	Sewer and Drain Line Contractor		
C-37b	Irrigation and Lawn Sprinkler Systems Contractor		
C-37c	Vacuum and Air Systems Contractor		
C-37d	Water Chlorination and Sanitation Contractor		
C-37e	Treatment and Pumping Facilities Contractor		
C-37f	Fuel Dispensing Contractor		
C-38	Post Tensioning Contractor		
C-40	Refrigeration Contractor		
C-40a	Prefabricated Refrigerator Panels Contractor		
C-41	Reinforcing Steel Contractor		
C-42	Roofing Contractor		
C-42a	Aluminum and Other Metal Shingles Contractor		
C-42b	Wood Shingles and Wood Shakes Contractor		
C-42c	Concrete and Clay Tile Contractor		
C-42e	Urethane Foam Contractor		
C-42g	Roof coatings Contractor		
C-43	Sewer, Sewage Disposal, Drain, and Pipe Laying Contractor		
C-43a	Reconditioning and Repairing Pipeline Contractor		
C-44	Sheet Metal Contractor		
C-44a	Gutters Contractor		
C-44b	Awnings and Patio Cover Contractor		
C-48	Structural Steel Contractor		
C-48a	Steel Door Contractor		
C-49b	Hot Tub and Pool Contractor		
C-51	Tile Contractor		



	Contractor Classification	Name of Joint Contractor or Subcontractor	License Number
C-51a	Cultured Marble Contractor		
C-51b	Terrazzo Contractor		
C-52	Ventilating and Air Conditioning Contractor		
C-55	Waterproofing Contractor		
C-56	Welding Contractor		
C-57	Well Contractor		
C-57a	Pumps Installation Contractor		
C-57b	Injection Well Contractor		
C-60	Solar Power Systems Contractor		
C-61	Solar Energy Systems Contractor		
C-61a	Solar Hot Water Systems Contractor		
C-61b	Solar Heating and Cooling Systems Contractor		
C-62	Pole and Line Contractor		
C-62a	Pole Contractor		
C-63	High Voltage Electrical Contractor		
C-68	Classified Specialist		
	Licensed Surveyor		
	Licensed Geotechnical Engineer		
	Licensed Structural Engineer		
	Archaeologist		
	Cultural Monitor		
	Licensed Civil Engineer		
	Supervising Control and Data Acquisition (SCADA) Contractor		
	NACE Inspector		
*			
*			
*			

^{*} Contractor to add licenses as required to complete the scope of work. Attach additional sheet as needed.



It is understood and agreed that the Department reserves the right to reject any and/or all offers and waive any defects when, in the Department's opinion, such rejection or waiver shall be for the best interest of the Department.

For purpose of evaluating the criterion described in this solicitation, it is understood and agreed that offers will be compared on the basis of the Total Sum Offer which shall be considered to be the total sum of actual or corrected amounts proposed on each item. The offerors signed Offer shall constitute the Offeror's official offer. The Department reserves the right to designate the contract amount based on selected Offeror's Total Sum Offer depending on the funds available for this Project.

It is also understood and agreed that the work called for under this Project must and shall be completed within **Nine Hundred (900)** consecutive calendar days after written notice has been given to the successful Offeror to commence work. It is also understood and agreed that the quantities given herewith are approximate only and are subject to increase or decrease and that the undersigned will perform all quantities of work, as either increase or decrease, in accordance with the provisions of the specifications.

It is also understood and agreed that the estimated quantities shown for items for which a UNIT PRICE is listed in the Offer are only for the purpose of comparing on a uniform basis offers offered for the work under this contract, and the undersigned agrees that the undersigned is satisfied with and will not dispute said estimated quantities as a means of comparing the offers. It is understood and agreed that the Offeror will make no claims for anticipated profit or loss of profit because of a difference between quantities of the various classes of work done or the materials and equipment actually installed and the said estimated quantities. On UNIT PRICE offers, payment will be made only for the actual number of units incorporated into the finished project at the contract UNIT PRICE.

It is also understood and agreed that if the product of the UNIT PRICE offer and the number of units does not equal the total amount stated by the Offeror in the offer for any item, it will be assumed that the error was made in computing the total amount. For purpose of evaluating the criterion described in this solicitation, the stated UNIT PRICE alone will be considered as representing the Offeror's intention and the total amount offered on such item shall be considered to be the amount arrived at by multiplying the UNIT PRICE by the number of units.

It is also understood and agreed that the liquidated damages in the amount of \$1,000.00 for each and every calendar day in excess thereof prior to completion of the contract beyond the specified and approved completion date, shall be withheld from payments due to the Contractor, pursuant to the Damages for Delay provision contained in this solicitation.

It is also understood and agreed that if this offer is accepted, the successful offeror will contract with the Board and said offeror shall furnish the required bonds to the Board within ten (10) days from the date of receiving from the Board the contract prepared and ready for execution.

It is further understood and agreed that the successful offeror will provide all necessary materials, labor, tools, equipment, and other incidental necessary to do all the work and furnish all the materials specified in the contract in the manner and time herein prescribed and according to the requirements of the Department as therein set forth.

The undersigned further understands and agrees that by submitting this Offer, 1) the Offeror is declaring that the Offer is not in violation of Chapter 84, Hawai'i Revised Statutes, and 2) Offeror is certifying that the price(s) submitted was (were) independently arrived at without collusion.



It is also understood and agreed that if this Offer is accepted and the undersigned shall fail to or neglect to contract as aforesaid, the Board may determine that the offeror has abandoned the contract and thereupon forfeiture of the security accompanying the Offer shall operate and the same shall become the property of the Board.

Enclosed herewith is a Bidder's Bond (Bid Security)	()	for the sum
Surety Bond	()	
Legal Tender	()	
Certificate of Deposit	()	
Share Certificate	()	
Cashier's Check	()	
Treasurer's Check	()	
Teller's Check	()	
Certified Check	()	
f		DOLLARS
\$) payable to the Department o	f Water, being	not less than the sum required
nder Sub-Section 2.9 "Bid Security" of the "General Pr	ovisions for C	Construction Contracts of the
Denartment of Water" dated April 25, 2016		

Evidence of the undersigned Offeror having herewith furnished.	the authority to submit this Offer and to enter a contract is
	Respectfully submitted,
	Name of Offeror
	Authorized Signature
	Print/Type Name & Title of above
Address, Zip Code	
Telephone	
Contractor's License No.	
State of Hawai'i General Excise Tax Licer	nse No.
Federal Employer Identification No.	
Type of Organization: (Please designate)	 □ Sole Proprietorship □ Partnership □ Corporation □ Joint Venture □ Other (please specify)
State of Incorporation:	☐ Other (<i>please specify</i>)
Name of Performance Bond Surety Co.	
Address	
Authorized to do Business in the State of Ha	wai'i? □ Yes or □ No



If corporation, state who will sign contract and signatory's title:		
Name	Title	
Name	Title	
together with the signature(s) of the Officer(s) authoroporate seal affixed thereto. Evidence of the authoroporation SHALL be attached to this page and it to sign includes, but is not limited to, a copy of the corporate by-laws. (See HRS Ch. 415, Hawai'i But If the Offeror is a LIMITED LIABILITY COM forth on the Offer, together with the signature(s) of	ncluded in the Offer. Acceptable evidence of authority e articles of incorporation, corporate resolution, or usiness Corporation Act). IPANY, the legal name of the company shall be set f the member of the limited liability company or company authorized to sign on behalf of the entity.	
with the signature(s) of the General Partner(s) authorized to this page and included with the Offer. Acceptab	me of the firm shall be set forth on the Offer, together norized to sign on behalf of the partnership. Evidence of to sign on behalf of the partnership <u>SHALL</u> be attached ble evidence of authority to sign for the partnership rship registration statement or authorization signed by bs).	
If Offeror is a SOLE PROPRIETORSHIP , Offe	eror's signature shall be placed above.	



(APPROVED)



TRUEGRID® vs Geoblock® 5150

TRUEGRID® is committed to providing the best possible solution for permeable paving in all residential, commercial, and industrial applications. TRUEGRID® is The World's Strongest Permeable Paver and is unmatched in engineering, performance, and longevity.








	TRUEGRID® PRO PLUS®	TRUEGRID® PRO LITE®	Geoblock® 5150
Compressive Strength	17,729 psi 12,465 t/m²	17,729 psi 12,465 t/m²	7,058 psi 4962 t/m²
Tensile Strength	2116 psi 14589 kPa	1335 psi 9205 kPa	Not Tested / Not Tested / Disclosed
Unit Configuration	Rigid and Flexible	Rigid and Flexible	Rigid X
Easy Unit Placement - No Special Patterns for Traffic Directions	Yes	Yes	No X
Self-Anchoring - Does Not Require Slope/Perimeter Anchors	Yes	Yes	No X
Available Markers/Delineators	Yes	Yes	No X
Installation Time	1000 sq ft / hr 100 m² / hr	1000 sq ft / hr 100 m² / hr	500 sq ft / hr 50 m²/ hr
Dimensions	1.8 in x 24 in x 24 in 4.6 cm x 61 cm x 61 cm	1 in x 24 in x 24 in 2.5 cm x 61 cm x 61 cm	2 in x 20 in x 40 in 5 cm x 50 cm x 100 cm

TRUEGRID® | TRUE ADVANTAGES



TRUEGRID® S-Flex joints move with freeze-thaw cycles & heaving soils.



Co-joined cylinder walls provide extreme compressive strength --The World's Strongest.



TRUEGRID® is self anchoring with X-Anchors. No additional staking needed.



Three-point locking tabs secure the units together with high tensile strength.



100% recycled high impact plastic with UV inhibitors provide a long lifespan: 25-60+ years.

All information provided is deemed reliable at the time of publication, but is not guaranteed. TRUEGRID®, PRO PLUS® & PRO LITE® are registered trademarks of Airlite Plastics™. Geoblock® 5150 is a registered trademark of Presto Products Company. TRUEGRID: The intellectual property leader in permeable paver technology. US Pat. No's: 8,734,049; 9,670,624; 9,617,698; 9,909,264; 9,909,266, 10,072,383, D792,987.

Additional US and Foreign Patents Pending. © Copyright 2019 TRUEGRID® Pavers. All Rights Reserved.

IFB Job No. 02-14, Addendum No. 3 Material Substitution Request No. 2 (APPROVED-35 pages)



PO Box 720 * Kula, Hi 96790 Tel: (808) 235-6307 Email: bob@cbchawaii.com

February 17, 2023

Department of Water, County of Kauai Engineering Division ATTN: Jason Kagimoto, PE - Procurement Officer 4398 Pua Loke Street Lihue, HI 96766

Subject: Request for Substitution

Project Title: WK-08, Kapa'a Homesteads 325' Tanks - Job No. 02-14

We hereby submit for substitution, with attached technical brochures, specifications and statement of variances for your review and approval for the items shown below.

SECTION BRAND SUBSTITUTE OR

NUMBER SPECIFIED ALTERNATE VARIANCE

SP-10.02.F

Press.Transmitter Rosemount 3051T ABB 266DSH None

Note: ABB 266DSH DP transmitter with 3-valve manifold is called out in project Plan C-16 item #15. The PFS Venturi Flow Metering Systems includes as its package, the Stainless Steel NEMA 4X enclosure with window along with its stand as described on Plan C-16 "VENTURI METER DIFFERENTIAL PRESSURE TRANSMITTER HOOK-UP AND MOUNTING SCHEMATIC".

I certify that substitution request of the above item meets as equivalent to the specified equipment in size, function and operational requirements.

Sincerely,

Bob Lake

Bob Lake

CBC Inc.



ABB MEASUREMENT & ANALYTICS | DATA SHEET

266DSH

Differential pressure transmitters



Measurement made easy

Engineered solutions for all applications

Base accuracy

from 0.06 % of calibrated span (optional 0.04 %)

Reliable sensing system coupled with very latest digital technologies

• provides large turn down ratio up to 100:1

Comprehensive sensor choice

optimize in-use total performance and stability

10-year stability

• 0.15 % of URL

Flexible configuration facilities

· provided locally via local LCD keypad

New TTG (Through-The-Glass) keypad technology

• allows quick and easy local configuration without opening the cover, even in explosion proof environments

IEC 61508 certification

version for SIL2 (1001) and SIL3 (1002) applications

PED compliance

- Category III for PS > 20 MPa, 200 bar
- Sound Engineering Practice (SEP) for PS ≤ 20 MPa, 200 bar

WirelessHART version

• the battery powered solution compliant to IEC 62591

Best-in-class battery life

- up to 10 years @ 32 s update time
- in-field replaceable

Product in compliance with Directive 2011/65/UE (RoHS II)

In-built advanced diagnostics

Specification - functional

Range and span limits

Sensor	Upper range limit	Lower range limit	Minimum
code	(URL)	(LRL)	measuring span
A	1 kPa	–1 kPa	0.05 kPa
	10 mbar	–10 mbar	0.5 mbar
	4 inH2O	–4 inH2O	0.2 inH2O
В	4 kPa	-4 kPa	0.2 kPa
	40 mbar	-40 mbar	2 mbar
	16 inH20	-16 inH2O	0.8 inH2O
E	16 kPa	–16 kPa	0.54 kPa
	160 mbar	–160 mbar	5.4 mbar
	64 inH2O	–64 inH2O	2.16 inH2O
F	40 kPa	–40 kPa	0.4 kPa
	400 mbar	–400 mbar	4 mbar
	160 inH2O	–160 inH2O	1.6 inH2O
Н	160 kPa	–160 kPa	1.6 kPa
	1600 mbar	–1600 mbar	16 mbar
	642 inH2O	–642 inH2O	6.4 inH2O
М	600 kPa	–600 kPa	6 kPa
	6 bar	–6 bar	0.06 bar
	87 psi	–87 psi	0.87 psi
P	2400 kPa	–2400 kPa	24 kPa
	24 bar	–24 bar	0.24 bar
	348 psi	–348 psi	3.5 psi
Q	8000 kPa	–8000 kPa	80 kPa
	80 bar	–80 bar	0.8 bar
	1160 psi	–1160 psi	11.6 psi
S	16000 kPa	–16000 kPa	160 kPa
	160 bar	–160 bar	1.6 bar
	2320 psi	–2320 psi	23.2 psi

Span limit

Maximum span = URL

(can be further adjusted up to ± URL (TD = 0.5) for differential models, within the range limits)
IT IS RECOMMENDED TO SELECT THE TRANSMITTER SENSOR CODE PROVIDING THE TURNDOWN VALUE AS LOWEST AS POSSIBLE TO OPTIMIZE PERFORMANCE CHARACTERISTICS.

Zero suppression and elevation

Zero and span can be adjusted to any value within the range limits detailed in the table as long as:

– calibrated span \geq minimum span

Damping (feature not available for WirelessHART version)

Selectable time constant : between 0 and 60 s This is in addition to sensor response time.

Turn on time

Operation within specification in less than 10 s with minimum damping.

Insulation resistance

> 100 $\mbox{M}\Omega$ at 500 V DC (terminals to earth)

Specification - operative limits

Pressure limits

Overpressure limits

The differential pressure transmitters, models 266DSH, work without damage within the following pressure limits:

Sensors	Fill fluid	Overpressure limits
Sensor F to S	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 21 MPa, 210 bar, 3045 psi (1) (2)
Sensor F to Q 266DSH High Static	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 42 MPa, 420 bar, 6090 psi
Sensor E	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 16 MPa, 160 bar, 2320 psi ⁽¹⁾
Sensor B	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 7 MPa, 70 bar, 1015 psi ⁽¹⁾
Sensor A	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 2 MPa, 20 bar, 290 psi ⁽¹⁾
Sensor F to S	Inert (Galden)	0.135 kPa abs, 1.35 mbar abs, 1 mmHg and 21 MPa, 210 bar, 3045 psi ⁽¹⁾ (2)
Sensor E	Inert (Galden)	0.135 kPa abs, 1.35 mbar abs, 1 mmHg and 16 MPa, 160 bar, 2320 psi ⁽¹⁾
Sensor F to S	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 21 MPa, 210 bar, 3045 psi ⁽¹⁾ ⁽²⁾
Sensor F to Q 266DSH High Static	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 42 MPa, 420 bar, 6090 psi
Sensor E	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 16 MPa, 160 bar, 2320 psi ⁽¹⁾

- (1) 1 MPa, 10 bar, 145 psi for Kynar-PVDF
- (2) 16 MPa, 160 bar, 2320 psi for AISI 316 ss NACE "exposed bolting"

For flange mounted version

Flange	Fill fluid	Overpressure limits
ASME B16.5 Class 150	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 230 psi
ASME B16.5 Class 300	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 600 psi
EN 1092-1 PN 16	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 13.5 bar
EN 1092-1 PN 40	Silicone oil	0.07 kPa abs, 0.7 mbar abs, 0.5 mmHg and 33.8 bar
ASME B16.5 Class 150	Inert (Galden)	0.135 kPa abs, 1.35 mbar abs, 1 mmHg and 230 psi
ASME B16.5 Class 300	Inert (Galden)	0.135 kPa abs, 1.35 mbar abs, 1 mmHg and 600 psi
EN 1092-1 PN 16	Inert (Galden)	0.135 kPa abs, 1.35 mbar abs, 1 mmHg and 13.5 bar
EN 1092-1 PN 40	Inert (Galden)	0.135 kPa abs, 1.35 mbar abs, 1 mmHg and 33.8 bar
ASME B16.5 Class 150	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 230 psi
ASME B16.5 Class 300	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 600 psi
EN 1092-1 PN 16	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 13.5 bar
EN 1092-1 PN 40	Inert (Halocarbon)	0.4 kPa abs, 4 mbar abs, 3 mmHg and 33.8 bar

Static pressure limits

The differential pressure transmitters, models 266DSH work within specifications between the following limits:

Sensors	Static pressure limits
Sensor F to S	1.3 kPa abs, 13 mbar abs, 0.2 psia and 21 MPa, 210 bar, 3045 psi ⁽¹⁾ (2)
Sensor F to Q 266DSH High Static	1.3 kPa abs, 13 mbar abs, 0.2 psia and 42 MPa, 420 bar, 6090 psi
Sensor E	1.3 kPa abs, 13 mbar abs, 0.2 psia and 16 MPa, 160 bar, 2320 psi ⁽¹⁾
Sensor B	1.3 kPa abs, 13 mbar abs, 0.2 psia and 7 MPa, 70 bar, 1015 psi (1)
Sensor A	1.3 kPa abs, 13 mbar abs, 0.2 psia and 2 MPa, 20 bar, 290 psi ⁽¹⁾

- (1) 1 MPa, 10 bar, 145 psi for Kynar-PVDF
- (2) 16 MPa, 160 bar, 2320 psi for AISI 316 ss NACE "exposed bolting"

Flange	Static pressure limits
ASME B16.5 Class 150	1.3 kPa abs, 13 mbar abs, 0.2 psia and 230 psi
ASME B16.5 Class 300	1.3 kPa abs, 13 mbar abs, 0.2 psia and 600 psi
EN 1092-1 PN 16	1.3 kPa abs, 13 mbar abs, 0.2 psia and 13.5 bar
EN 1092-1 PN 40	1.3 kPa abs, 13 mbar abs, 0.2 psia and 33.8 bar

The pressure limit decreases with increasing temperature above 100°F (38°C), according to ASME B16.5 standards or above 50°C according to EN 1092-1 standards.

Proof pressure

The transmitterwith threaded process connection can be exposed without leaking to line pressure of up to

- 48 MPa, 480 bar, 6960 psi for standard static version
- 77 MPa, 770 bar, 11165 psi for high static version.
- up to two times the flange rating for the flange mounted version.

Meet ANSI/ISA-S 82.03 hydrostatic test requirements.

Temperature limits °C (°F)

Ambient

is the operating temperature

Models 266DSH	Ambient temperature limits
Silicone oil for sensor F to S	–40 and 85 °C (–40 and 185 °F)
Silicone oil for sensor A to E	–25 and 85 °C (–13 and 185 °F)
Inert (Galden) for sensor F to S	–20 and 85 °C (–4 and 185 °F)
Inert (Galden) for sensor E	–10 and 85 °C (14 and 185 °F)
Inert (Halocarbon) for sensor F to S	–20 and 85 °C (–4 and 185 °F)
Inert (Halocarbon) for sensor E	–10 and 85 °C (14 and 185 °F)

Models 266DSH	Ambient temperature limits
LCD integral display	–40 and 85 °C (–40 and 185 °F)

LCD display may not be clearly readable below –20 °C (–4 °F) or above +70 °C (+158 °F)

IMPORTANT

For Hazardous Atmosphere applications see the temperature range specified on the certificate/approval relevant to the aimed type of protection

Process

Models 266DSH	Process temperature limits
Silicone oil for sensor F to S	–40 and 121 °C (–40 and 250 °F) ⁽¹⁾
Silicone oil for sensor A to E	–25 and 121 °C (–13 and 250 °F) ⁽¹⁾
Inert (Galden) for sensor F to S	–20 and 100 °C (–4 and 212 °F) ⁽²⁾
Inert (Galden) for sensor E	–10 and 100 °C (14 and 212 °F) ⁽²⁾
Inert (Halocarbon) for sensor F to S	–20 and 100 °C (–4 and 212 °F) ⁽²⁾
Inert (Halocarbon) for sensor E	–10 and 100 °C (14 and 212 °F) ⁽²⁾

(1) 100 °C (212 °F) for application below atmospheric pressure (2) 65 °C (150 °F) for application below atmospheric pressure

Models 266DSH	Process temperature limits
Viton gasket	–20 and 121 °C (–4 and 250 °F)

Storage

Models 266DSH	Storage temperature limits
Storage limits	–50 and 85 °C (–58 and 185 °F)
LCD integral display	–40 and 85 °C (–40 and 185 °F)

Environmental limits

Electromagnetic compatibility (EMC)

Comply with 2014/30/UE to standards EN 61326-1:2013. For IEC 61508 SIL certified transmitter to

EN 61326-3-1:2008.

For transmitter with option "YE" to NAMUR NE 021 (2004). Surge immunity level (with surge protector): 4 kV (according to IEC 61000-4–5 EN 61000–4–5)

Pressure equipment directive (PED)

Comply with 2014/68/UE to standards
ANSI/ISA 61010-1:2012
Category III Module H for PS ≥ than 20 MPa, 200 bar
Sound Engineering Practice (SEP) for PS < 20 MPa, 200 bar

Humidity

Relative humidity: up to 100 % Condensing, icing: admissible

Vibration resistance

Accelerations up to 2 g at frequency up to 1000 Hz (according to IEC 60068–2–6)

Shock resistance

Acceleration: 50 g Duration: 11 ms

(according to IEC 60068-2-27)

Wet and dust-laden atmospheres

The transmitter is dust and sand tight and protected against immersion effects as defined by IEC 60529 (2001) to IP 67 (IP 68 on request) or by NEMA Type 4X.

IP65 with Harting Han connector.

Aluminium and AISI housings as barrel version also comply to IP 66 as defined by IEC 60529 (2001).

IP66W/IP67W/IP68W as standard for Inmetro certification.

Specification - operative limits

Hazardous atmospheres

(FOR ALL VERSIONS EXCEPT WirelessHART)

With or without integral display

INTRINSIC SAFETY Ex ia:

ATEX Europe (code E1) approval

II 1 G Ex ia IIC T6...T4 Ga and II 1/2 G Ex ia IIC T6...T4 Ga/Gb and

II 1 D Ex ia IIIC T85 °C Da and II 1/2 D Ex ia IIIC T85 °C Da; IP67.

IECEx (code E8) approval

Ex ia IIC T6...T4 Ga/Gb and Ex ia IIIC T85 °C Da; IP67.

NEPSI China (code EY)

Ex ia IIC T4/T5/T6 Ga, Ex ia IIC T4/T5/T6 Ga/Gb,

Ex iaD 20 T85/T100/T135, Ex iaD 20/21 T85/T100/T135.

EXPLOSION PROOF:

ATEX Europe (code E2) approval

II 1/2 G Ex db IIC T6 Ga/Gb Ta=–50 °C to +75 °C and

II 1/2 D Ex tb IIIC T85 °C Db Ta = -50 °C to +75 °C; IP67.

IECEx (code E9) approval

Ex db IIC T6 Ga/Gb Ta=–50 °C to +75 °C and

Ex tb IIIC T85 °C Db Ta = -50 °C to +75 °C; IP67.

NEPSI China (code EZ)

Ex d IIC T6 Gb, Ex tD A21 IP67 T85 °C.

INTRINSIC SAFETY Ex ic:

ATEX Europe (code E3) type examination

II 3 G Ex ic IIC T6...T4 Gc and II 3 D Ex tc IIIC T85 °C Dc; IP67.

IECEx (code ER) type examination

Ex ic IIC T6...T4 Gc and Ex tc IIIC T85 °C Dc; IP67.

NEPSI China (code ES) type examination

Ex ic IIC T4~T6 Gc, Ex nA IIC T4~T6 Gc, Ex tD A22 IP67 T85 °C.

FM Approvals US (code E6) and FM Approvals Canada (code E4):

- Explosionproof (US): Class I, Division 1, Groups A, B, C, D; T5
- Explosionproof (Canada): Class I, Division 1, Groups B, C, D; T5
- Dust-ignitionproof: Class II, Division 1, Groups E, F, G; Class III, Div. 1; T5
- Flameproof (US): Class I, Zone 1 AEx d IIC T4 Gb $\,$
- Flameproof (Canada): Class I, Zone 1 Ex d IIC T4 Gb
- Nonincendive: Class I, Division 2, Groups A, B, C, D T6...T4
- Energy limited (US): Class I, Zone 2 AEx nC IIC T6...T4
- Energy limited (Canada): Class I, Zone 2 Ex nC IIC T6...T4
- Intrinsically safe: Class I, II, III, Division 1, Groups A, B, C, D, E, F, G T6...T4 Class I, Zone 0 AEx ia IIC T6...T4 (US)

 ${\it Class I, Zone \, 0 \, Ex \, ia \, IIC \, T6...T4 \, (Canada)} \\ {\it Type \, 4X, IP67 \, for \, all \, above \, markings.}$

COMBINED FM Approvals US and Canada

- Intrinsically safe (code EA)

COMBINED ATEX, FM and IECEx Approvals (code EN)

Technical Regulations Customs Union EAC (Russia, Kazakhstan, Belarus), Inmetro (Brazil), Kosha (Korea)

(ONLY FOR WirelessHART VERSION)

With or without integral display

INTRINSIC SAFETY:

ATEX Europe (code E1) approval

II 1 G Ex ia IIC T4 and II 1/2 G Ex ia IIC T4.

IECEx (code E8) approval

Ex ia IIC T4.

FM Approvals US and FM Approvals Canada:

Intrinsically safe:Class I, Div. 1, Groups A, B, C, D; T4 (code EA)
 Class I, Zone O AEx ia IIC T4, Gb (FM US)

Class I, Zone 0 Ex ia IIC T4, Gb (FM Canada)

IMPORTANT

REFER TO CERTIFICATES FOR AMBIENT TEMPERATURE RANGES RELATED TO THE DIFFERENT TEMPERATURE CLASSES.

HIGH STATIC VERSION IS NOT IN COMPLIANCE WITH ISA 12.27.01 FOR SEALING REQUIREMENTS, SPECIFICALLY FOR FM APPROVAL (Canada).

Electrical Characteristics and Options

Optional indicators

Integrated digital display

(code LS; only with HART standard functionality)

Wide screen LCD, 128 x 64 pixel,

52.5 x 27.2 mm (2.06 x 1.07 in.) dot matrix.

Two keys for zero/span or without keypad.

User selectable application-specific

visualizations.

Display may also indicate static pressure, sensor temperature and diagnostic messages.

Integral display with integral keypad (code L1; not with HART standard functionality)

Wide screen LCD, 128 x 64 pixel, 52.5 x 27.2 mm (2.06 x 1.07 in.) dot matrix. Multilanguage. Four keys for configuration

and management of device.

Easy setup for quick commissioning. User selectable application-specific visualizations.

Totalized and instantaneous flow indication.

Display may also indicate static pressure, sensor temperature and diagnostic messages and provides configuration facilities.

Integral display with Through-The-Glass (TTG) activated keypad (code L5; not with HART standard functionality)

As above integral display but equipped with the innovative TTG keypad allowing the activation of the configuration and management menus of the device without the need of removing the transmitter housing cover. TTG keypad is protected against accidental activations.



Optional surge protection

Up to 4kV

- voltage 1.2 μs rise time / 50 μs delay time to half value
- current 8 μ s rise time / 20 μ s delay time to half value

Process diagnostics (PILD)

Plugged impulse line detection (PILD) generates a warning via communication (HART, PA, FF). The device can be configured to drive the output to "Alarm current" or set a status "BAD".

HART° digital communication and 4 to 20 mA output – Standard and Advanced functionality

Device type: 1a06hex (listed with HCF)

Power supply

The transmitter operates from 10.5 to 42 V DC with no load and is protected against reverse polarity connection (additional load allows operations over 42 V DC). For Ex ia and other intrinsically safe approval power supply must not exceed 30 V DC. Minimum operating voltage increases to 12.3 V DC with optional surge protector or to 10.8 V DC with optional conformity to NAMUR NE 21 (2004).

Ripple

20 mV max on a 250 Ω load as per HART specifications.

Load limitations

4 to 20 mA and HART total loop resistance:

R ($k\Omega$)= Supply voltage – min. operating voltage (V DC)

A minimum of 250 Ω is required for HART communication.

Output signal

Two–wire 4 to 20 mA, user-selectable for linear or square root output, power of $^3/2$ or $^5/2$, square root for bidirectional flow, 22 points linearization table (i.e. for horizontal or spherical tank level measurement). HART° communication provides digital process variable superimposed on 4 to 20 mA signal, with protocol based on Bell 202 FSK standard.

HART revision 7 is the default HART output. HART revision 5 is selectable on request.

Output current limits (to NAMUR NE 43 standard)

Overload condition

- Lower limit: 3.8 mA (configurable from 3.8 to 4 mA)
- Upper limit: 20.5 mA (configurable from 20 to 21 mA) Alarm current
- Lower limit: 3.6 mA (configurable from 3.6 to 4 mA)
- Upper limit: 21 mA (configurable from 20 to 23 mA, limited to 22 mA for HART Safety; apply for electronics release 7.1.15 or later)

Factory setting: high alarm current.

...Specification – electrical characteristics and options

IEC 62591 WirelessHART® output

Device type: 1a06hex (listed with HCF) Network ID: ABBhex (2747 decimal)

Join keys: 57495245hex (1464422981) 4c455353hex (1279611731) 4649454chex (1179206988) 444b4559hex (1145783641).

Power Supply

1x D-cell size lithium-thionyl chloride battery. Battery life: 10 years at 32 sec. update time, 8 years at 16 sec. update time or 5 years at 8 sec. update time. (at reference conditions of 25 ± 2 °C ambient temperature, data routed from 3 additional devices, LCD off).

THE BATTERY CAN BE REPLACED IN FIELD, ALSO IN HAZARDOUS CLASSIFIED AREA.

Output signal

IEC 62591 WirelessHART Version 7.5 (IEEE 802.15.4-2006); Frequency band: 2.4 GHz DSSS

Update rate: user selectable from 1 sec. to 60 min.

Integrated adjustable omnidirectional antenna

- Output radio frequency: maximum 10 mW (10 dBm) EIRP
- Range: up to 300 m. (328 yds.)

Minimum distance between antenna and person is 0.2 m. (8 in.)

Telecommunications directive

Every wireless measuring device must be certified in accordance with the telecommunications directive, in this case the frequency range. This certification is country-specific.

European directives

Radio Equipment & Telecommunications Terminal Equipment Directive 2014/53/UE to standards EN 60950-1:2013,

EN 62311:2008, EN 301 489-1 V1.9.2, EN 301 489-17 V2.2.1, EN 300 328 v1.8.1.

In Europe, use of the 2400 - 2483.5 MHz frequency band is not harmonized. Country-specific regulations must be observed.

Restrictions for Norway

Operation not permitted within a radius of 20 km around Ny-Alesund in Svalbard. For more information, see www.npt.no Norway Posts and Telecommunications site

Extra-european radio frequency licences

USA to FCC Part 15.247:2009; Canada to IC RSS-210 and ICES-003; Argentina; United Arab Emirates (UAE); India; Mexico.

PROFIBUS® PA output

Device type

Pressure transmitter compliant to Profiles 3.0.1 Identification number: 3450 (hex)

Power supply

The transmitter operates from 9 to 32 V DC , polarity independent, with or without surge protector. For Ex ia approval power supply must not exceed 17.5 V DC. Intrinsic safety installation according to FISCO model.

Current consumption

operating (quiescent): 15 mA fault current limiting: 20 mA max.

Output signal

Physical layer in compliance to IEC 1158–2/EN 61158–2 with transmission to Manchester II modulation, at 31.25 kbit/s.

Output interface

PROFIBUS PA communication according to Profibus DP50170 Part 2/DIN 19245 part 1–3.

Output update time

25 ms

Data blocks

3 analog input, 1 physical.

Additional blocks

1 Pressure with calibration transducer block

1 Advanced Diagnostics transducer block including

Plugged Input Line Detection

1 Local Display transducer block

Transmitter failure mode

On gross transmitter failure condition, detected by selfdiagnostics, the output signal can be driven to defined conditions, selectable by the user as safe, last valid or calculated value.

If electronic failure or short circuit occur the transmitter consumption is electronically limited at a defined value (20 mA approx), for safety of the network.

FOUNDATION FieldbusTM output

Device type

LINK MASTER DEVICE

Link Active Scheduler (LAS) capability implemented.

Manufacturer code: 000320_{hex} Device type code: 0007_{hex}

Power supply

The transmitter operates from 9 to 32 V DC, polarity independent, with or without surge protector. For Ex ia approval power supply must not exceed 24 V DC (FF–816 certification) or 17.5 V DC (FISCO certification).

Current consumption

operating (quiescent): 15 mA fault current limiting: 20 mA max.

Output signal

Physical layer in compliance to IEC 61158–2/EN 61158–2. Transmission to Manchester II modulation, at 31.25 kbit/s.

Function blocks/execution period

3 enhanced Analog Input blocks/25 ms max (each)

- 1 enhanced PID block/40 ms max.
- 1 standard ARitmetic block/25 ms
- 1 standard Input Selector block/25 ms
- 1 standard Control Selector block/25 ms
- 1 standard Signal Characterization block/25 ms
- 1 standard Integrator/Totalizer block/25 ms

Additional blocks

1 enhanced Resource block.

1 custom Pressure with calibration transducer block

1 custom Advanced Diagnostics transducer block

including Plugged Input Line Detection

1 custom Local Display transducer block

Number of link objects

35

Number of VCRs

35

Output interface

FOUNDATION fieldbus digital communication protocol to standard H1, compliant to specification V. 1.7.

Transmitter failure mode

The output signal is "frozen" to the last valid value on gross transmitter failure condition, detected by self-diagnostics which also indicate a BAD conditions. If electronic failure or short circuit occur the transmitter consumption is electronically limited at a defined value (20 mA approx), for safety of the network.

Specification - performance

Stated at reference condition to IEC 60770 ambient temperature of 20 °C (68 °F), relative humidity of 65 %, atmospheric pressure of 1013 hPa (1013 mbar), mounting position with vertical diaphragm and zero based range for transmitter with isolating diaphragms in AISI 316 L ss or Hastelloy and silicone oil fill and HART digital trim values equal to 4 mA and to 20 mA span end points, in linear mode.

Unless otherwise specified, errors are quoted as % of span.

Some performance referring to the Upper Range Limit are affected by the actual turndown (TD) as ratio between Upper Range Limit (URL) and calibrated span. IT IS RECOMMENDED TO SELECT THE TRANSMITTER SENSOR CODE PROVIDING THE TURNDOWN VALUE AS LOWEST AS POSSIBLE TO OPTIMIZE PERFORMANCE CHARACTERISTICS.

Dynamic performance (according to IEC 61298–1 definition)

Sensors	Total response time
Sensor F to S	\leq 100 ms ⁽¹⁾

Total response time for sensor E \leq 130 ms, for sensor B \leq 310 ms $^{(1)}$

(1) Availability subject to special request for sensors B to H and not applicable for explosionproof and flameproof.

Total response time includes dead time of 30 ms (for all sensors) with time constant @ 63.2 % of total step change. See "Update Rate" for WirelessHART version.

Accuracy rating

% of calibrated span, including combined effects of terminal based linearity, hysteresis and repeatability. For fieldbus versions SPAN refer to analog input function block outscale range

Model	Sensor	for TD	
266DSH	F to P	from 1:1 to 10:1	± 0.06 %
266DSH standard static and for gauge application E B B B A A A 266DSH (option D2) F to Q C C C C C C C C C C C C C C C C C C	F to P	from 10:1 to 100:1	± (0.006 x TD) %
	E, Q, S	from 1:1 to 10:1	± 0.075 %
application	F to P andard atic and r gauge pplication E B B A A 66DSH F to Q pption D2) F to P Q 66DSH F to P Q	from 10:1 to 100:1	± (0.0075 x TD) %
266DSH standard static and for gauge application 266DSH E B B B A A A Coption D2) F to Q Coption D2 F to Q Coption D2 F to P Q Coption Static F to Q bigh static	from 10:1 to 30:1	± (0.0075 x TD) %	
	В	from 1:1 to 10:1	± 0.10 %
	В	from 10:1 to 20:1	± (0.01 x TD) %
	A	from 1:1 to 4:1	± 0.10 %
	A	from 4:1 to 20:1	± (0.025 x TD) %
	F to Q	from 1:1 to 5:1	± 0.04 %
	F to P	from 5:1 to 100:1	± (0.0105 + 0.0059 x TD) %
	Q	from 5:1 to 100:1	± (0.003 + 0.0074 x TD) %
Q 266DSH F to Q		from 1:1 to 10:1	± 0.075 %
zeed DSH static	F to Q	from 10:1 to 100:1	± (0.0075 x TD) %

Ambient temperature

per 20K change between the limits of –40 °C to +85 °C (per 36 °F change between the limits of –40 to +185 °F):

Model	Sensor	for TD up to	
266DSH	F to Q	10:1	± (0.03 % URL + 0.045 % span)
	E and S	10:1	± (0.04 % URL + 0.065 % span)
	В	10:1	± (0.06 % URL + 0.10 % span)
	A	4:1	± (0.10 % URL + 0.10 % span)

for an ambient temperature change from -10 °C to +60 °C (+14 to +140 °F):

Model	Sensor	for TD up to	
266DSH	F to Q	10:1	± (0.055 % URL + 0.08 % span)
	E and S	10:1	± (0.075 % URL + 0.11 % span)
	В	10:1	± (0.11 % URL + 0.18 % span)
	A	4:1	± (0.18 % URL + 0.18 % span)

per 10K change between the limits of -40 °C to -10 °C or +60° to +85 °C (per 18 °F change between the limits of -40 to +14 °F or +140° to +185 °F):

Model	Sensor	for TD up to	
266DSH	F to Q	10:1	± (0.03 % URL + 0.04 % span)
	E and S	10:1	± (0.04 % URL + 0.055 % span)
	В	10:1	± (0.055 % URL + 0.09 % span)
	A	4:1	± (0.09 % URL + 0.09 % span)

Static pressure

(zero errors can be calibrated out at line pressure) per 0.5 MPa, 5 bar or 72.5 psi (sensor A) per 2 MPa, 20 bar or 290 psi (sensor B) per 3.5 MPa, 35 bar or 500 psi (sensor E) per 7 MPa, 70 bar or 1015 psi (sensor F to S) Model 266DSH standard static

- zero error: ±0.05 % of URL for sensor F to S
 ±0.08 % of URL for sensor A, B and E
- span error: ±0.08 % of reading.

Model 266DSH high static

• zero error: ±0.08 % of URL for sensor F to Q

• span error: ±0.20 % of reading. Model 266DSH flange mounted per 2 MPa, 20 bar or 290 psi

zero error: ±0.05 % of URL for sensor F to P
 ±0.08 % of URL for sensor E

span error: ±0.08 % of reading.

Supply voltage

Within voltage/load specified limits the total effect is less than $0.005\,\%$ of URL per volt.

Load

Within load/voltage specified limits the total effect is negligible.

Electromagnetic field

Meets all the requirements of EN 61326 for surge immunity level (of NAMUR NE 21 on request).

Common mode interference

No effect from 100Vrms @ 50Hz, or 50 V DC

Mounting position

No effect for rotation on diaphragm plane. A tilt up to 90° from vertical causes a zero shifts up to 0.5 kPa, 5 mbar or 2 inH2O, which can be corrected with zero adjustment. No span effect.

Stability

 ± 0.15 % of URL over a ten years period (± 0.25 % of URL over a ten years period for sensor A or B) 0.15 % of URL over a five years period for 266DSH high static.

Maximum total performance

For temperature change of 28 °C (50 °F), static pressure change of 5,1 MPa, 51 bar, 740 psi, for model 266DSH with accuracy option code D2 (\pm 0.04 %)

Sensor Span F 35 kPa, 350 mbar, 140 inH2O H 150 kPa, 1,5 bar, 600 inH2O M 550 kPa, 5,5 bar, 80 psi	Maximum total performance	
F	35 kPa, 350 mbar, 140 inH2O	≤± 0.125 % of calibrated span
Н	150 kPa, 1,5 bar, 600 inH2O	
М	550 kPa, 5,5 bar, 80 psi	

$$\mathsf{E}_{\mathsf{Mperf}} = \sqrt{(\mathsf{E}_{\mathsf{\Delta}\mathsf{Tz}} + \mathsf{E}_{\mathsf{\Delta}\mathsf{Ts}})^2 + \mathsf{E}_{\mathsf{\Delta}\mathsf{Ps}}^2 + \mathsf{E}_{\mathsf{lin}}^2}$$

E_{Mperf} = Maximum total performance

 $E_{\Delta Tz}$ = Effect of the ambient temperature on zero

 $E_{\Delta Ts}$ = Effect of the ambient temperature on span

 $E_{\Delta Ps}$ = Effect of the static pressure on span

Elin = Accuracy rating (for terminal-based linearity 0.04 %)

Total performance

similar to DIN 16086

Temperature change in the range from -10 to 60 °C (14 to 140 °F), static pressure change (266DSH) 10 MPa, 100 bar, 1450 psi

Model	Sensor	TD	Total performance
266DSH std. static, D2 option	F to Q	1:1	≤± 0.16 % of calibrated span

$$\mathsf{E}_{\mathsf{perf}} = \sqrt{\left(\mathsf{E}_{\Delta\mathsf{Tz}} + \mathsf{E}_{\Delta\mathsf{Ts}}\right)^2 + \mathsf{E}_{\Delta\mathsf{Ps}}^2 + \mathsf{E}_{\mathsf{lin}}^2}$$

E_{perf} = Total Performance

 $E_{\Delta Tz}$ = Effect of the ambient temperature on zero

 $E_{\Delta Ts}$ = Effect of the ambient temperature on span

 $E_{\Delta Ps}$ = Effect of the static pressure on span (266DSH only)

Elin = Accuracy rating (for terminal-based linearity 0.04 % or 0.075% as per model/sensor accuracy)

Maximum total performance and Total performance includes the measuring errors of

- non-linearity including hysteresis and nonreproducibility,
- thermal change of the ambient temperature as regards the zero signal and the calibrated span,
- effect of static pressure change on the calibrated span,
- · with transmitter re-zeroed at line pressure.

Specification - physical

(Refer to ordering information sheets for variant availability related to specific model or versions code)

Materials

Process isolating diaphragms (*)

AISI 316 L ss; AISI 316 L ss gold plated; Monel 400°; Tantalum; Hastelloy° C-276; Hastelloy° C-276 on AISI 316L ss gasket seat.

Process flanges, adapters, plugs and drain/vent valves (*)

AISI 316 L ss ⁽¹⁾; Hastelloy° C-276 ⁽²⁾; Monel 400° ⁽³⁾; Kynar° (PVDF insert in AISI 316 ss flange). AISI 316 L ss with flushing connections for high side of flange mounted version.

Sensor fill fluid

Silicone oil; Inert fill (Halocarbon® 4.2 or Galden®).

Mounting bracket (**)

Zinc plated carbon steel with chrome passivation; AISI 316 ss; AISI 316 L ss.

Gaskets (*)

Viton®; PTFE.

Sensor housing

AISI 316 L ss.

Bolts and nuts

AISI 316 ss bolts Class A4–80 and nuts Class A4–70 per ISO 3506;

AISI 316 ss bolts and nuts Class A4–50 per ISO 3506, in compliance with NACE MR0175 Class II (std. static only). Plated alloy steel bolts per ASTM-A-193-77a grade B7M and nuts per ASTM A194/A 194 M-90 grade 2HM, in compliance with NACE MR0175 Class II.

Stainless steel per ASTM-A-453 grade 660D, in compliance with NACE MR0175 Class II (high static only).

Electronic housing and covers

Aluminium alloy (copper content \leq 0.3 %) with baked epoxy finish (colour RAL9002); AISI 316 L ss.

Covers O-ring

Buna N.

Local adjustments (zero, span and write protect)

For Standard HART version:

- Internal for zero and span (on connection board)
- External non-intrusive for zero, span and write protect in glass filled polyphenylene oxyde, removable (code R1).

For all other versions:

• External non-intrusive for zero, span and write protect in glass filled polyphenylene oxyde, removable.

Plates

Transmitter nameplate: AISI 316 ss screwed to the electronics housing.

Certification plate and optional tag/calibration plate: self-adhesive attached to the electronics housing or AISI 316 ss fastened to the electronics housing with rivets or screws.

Optional wired-on customer data plate: AISI 316 ss. Laser printing on metal or thermal printing on self-adhesive.

For AISI 316 L ss housing it is mandatory to select option I2 or I3 for plates in AISI 316 ss.

Calibration

Standard: at maximum span, zero based range, ambient temperature and pressure;

Optional: at specified range and ambient conditions.

- (*) Wetted parts of the transmitter.
- (**)U-bolt material: high-strength alloy steel or AISI 316 L ss; bolts/nuts material: high-strength alloy steel or AISI 316 ss.
- $^{ ext{(1)}}$ Supplied as AISI 316 L or as ASTM A351 Grade CF-3M
- ⁽²⁾ Supplied as Hastelloy C-276 or as ASTM A494 alloy CW-12MW
- (3) Supplied as Monel 400 or as ASTM A494 Grade M-35-1

Optional extras

Mounting brackets (code Bx)

For vertical and horizontal 60mm. (2in) pipes or wall mounting. (EXCEPT U-BOLT ASSEMBLY WHICH IS NOT SUPPLIED FOR WALL MOUNTING, PARTS ARE THE SAME FOR PIPE AND WALL BRACKET OPTIONS, AS PER RELEVANT MATERIALS).

Display (code Lx)

4-position (at 90°) user orientable, except "LS".

Optional plates (code Ix)

Code I1: AISI 316 ss wired-on plate with laser printed customized data (4 lines of 32 characters with 4 mm/0.16 in. height).

Code I2: AISI 316 ss plate with laser printed tag (up to 31 characters) and calibration details (up to 31 characters: lower and upper range values and engineering unit) fixed onto transmitter housing.

Code I3: complete set of AISI 316 ss plates (see I1 and I2).

Surge protection (code S2)

Cleaning procedure for oxygen service (code P1)

Test Certificates (test, design, calibration, material traceability) (codes Cx and Hx)

Tag and manual language (codes Tx and Mx)

Manifold mounting (code A1)

Factory mounting and pressure test of ABB M26 manifolds.

Process connections

on flanges: 1/4 in. – 18 NPT on process axis on adapters: 1/2 in. – 14 NPT on process axis centre distance (266DSH): 54 mm. (2.13 in.) on flange; 51, 54 or 57 mm. (2.01, 2.13 or 2.24 in.) as per adapters fittings

fixing threads: 7/16 in. – 20 UNF at 41.3 mm centre

distance

High pressure side of flange mounted version (*): 2 in. or 3 in., ASME Class 150 or Class 300 RF; DN 50 or DN 80, PN 16 or PN 40 to EN 1092-1 Type B1

(*) Bolts and nuts, gasket and mating flange supplied by customer.

Electrical connections

Two 1/2 in. – 14 NPT or M20x1.5 threaded conduit entries, direct on housing. Only M20x1.5 for WirelessHART with one port used for antenna.

One certified stainless steel plug (supplied loose with thread according to housing entries) available as option.

Terminal block

HART version: three terminals for signal/external meter wiring up to 2.5 mm² (14 AWG), also connection points for test and communication purposes.

WirelessHART version: connection points for test and communication purposes; additional fast connection for external harvesting unit.

Fieldbus versions: two terminals for signal wiring (bus connection) up to 2.5 mm² (14 AWG)

Grounding

Internal and external 6 mm² (10 AWG) ground termination points are provided.

Mounting position

Transmitter can be mounted in any position. Electronics housing may be rotated to any position. A positive stop prevents over travel.

Mass (without options)

4 kg approx (8.8 lb) for standard static and gauge versions;

4.35 kg approx (9.6 lb) for high static version; 7 to 11 kg approx (16 to 24 lb) for flange mounted version; add 1.5 kg (3.3 lb) for AISI housing. Add 650 g (1.5 lb) for packing.

Packing

Carton 27 x 24 x 20 cm approx (11 x 10 x 8 in.); Carton 35 x 33 x 35 cm approx (14 x 13 x 14 in) for flange mounted version.

Specification – configuration

Transmitter with HART communication and 4 to 20 mA

Standard configuration

Transmitters are factory calibrated to customer's specified range. Calibrated range and tag number are stamped on the tag plate. If a calibration range and tag data are not specified, the transmitter will be supplied with the plate left blank and configured as follows:

Engineering Unit kPa 4 mA Zero

20 mA Upper Range Limit (URL)

Output Linear
Damping 1 s
Transmitter failure mode Upscale
Software tag (8 char. max) Blank

Optional LCD display PV in kPa; output in mA and

in percentage on bargraph

Any or all the above configurable parameters, including Lower range-value and Upper range-value which must be the same unit of measure, can be easily changed using the HART hand-held communicator or by a PC running the configuration software with DTM for 266 models. The transmitter database is customized with specified flange type and material, O-ring and drain/vent materials and meter code option.

Custom configuration (option N6)

The following data may be specified in addition to the standard configuration parameters:

Descriptor 16 alphanumeric characters
Message 32 alphanumeric characters

Date Day, month, year

For HART protocol available engineering units of pressure measure are:

Pa, kPa, MPa inH2O@4 °C, mmH2O@4 °C, psi inH2O@68 °F, ftH2O@68 °F, mmH2O@68 °F inHg, mmHg, Torr g/cm², kg/cm², atm mbar. bar

These and others are available for PROFIBUS and FOUNDATION Fieldbus.

Transmitter with WirelessHART communication

Standard configuration

Transmitters are factory calibrated to customer's specified range. Calibrated range and tag number are stamped on the tag plate. If a calibration range and tag data are not specified, the transmitter will be supplied with the plate left blank and configured as follows:

Engineering Unit kPa

Output scale 0 % Lower Range Limit (LRL)
Output scale 100 % Upper Range Limit (URL)

Output Linear Update time 16 s Software tag (8 char. max) Blank

Optional LCD display PV in kPa; output in

percentage on bargraph

Any or all the above configurable parameters, including Lower range-value and Upper range-value which must be the same unit of measure, can be easily changed using the HART hand-held communicator or by a PC running the configuration software with DTM for 266 models. The transmitter database is customized with specified flange type and material, O-ring and drain/vent materials and meter code option.

Custom configuration (option N6)

The following data may be specified in addition to the standard configuration parameters:

Descriptor 16 alphanumeric characters
Message 32 alphanumeric characters

Date Day, month, year

Transmitter with PROFIBUS PA communication

Standard configuration

Transmitters are factory calibrated to customer's specified range. Calibrated range and tag number are stamped on the tag plate. If a calibration range and tag data are not specified, the transmitter will be supplied with the plate left blank and configured as follows:

Measure Profile Pressure Engineering Unit kPa

Output scale 0 % Lower Range Limit (LRL)
Output scale 100 % Upper Range Limit (URL)

Output Linear

Hi-Hi Limit Upper Range Limit (URL)
Hi Limit Upper Range Limit (URL)
Low Limit Lower Range Limit (LRL)
Low-Low Limit Lower Range Limit (LRL)
Limits hysteresis 0.5 % of output scale

PV filter 0 s Address (set by local key) 126

Tag 32 alphanumeric characters
Optional LCD display PV in kPa; output in percentage

on bargraph

Any or all the above configurable parameters, including the range values which must be the same unit of measure, can be easily changed by a PC running the configuration software with DTM for 266 models. The transmitter database is customized with specified flange type and material, O-ring and drain/vent materials and meter code option.

Custom configuration (option N6)

The following data may be specified in addition to the standard configuration parameters:

Descriptor 32 alphanumeric characters Message 32 alphanumeric characters

Date Day, month, year

Transmitter with FOUNDATION Fieldbus communication

Standard configuration

Transmitters are factory calibrated to customer's specified range. Calibrated range and tag number are stamped on the tag plate. If a calibration range and tag data are not specified, the transmitter will be supplied with the plate left blank and the analog input function block FB1 is configured as follows:

Measure Profile Pressure Engineering Unit kPa

Output scale 0 % Lower Range Limit (LRL)
Output scale 100 % Upper Range Limit (URL)

Output Linear

Hi-Hi Limit Upper Range Limit (URL)
Hi Limit: Upper Range Limit (URL)
Low Limit Lower Range Limit (LRL) LowLow Limit Lower Range Limit (LRL)
Limits hysteresis 0.5 % of output scale

PV filter time 0 s

Tag 32 alphanumeric characters
Optional LCD display PV in kPa; output in percentage

on bargraph

The analog input function block FB2 and FB3 are configured respectively for the sensor temperature measured in °C and for the static pressure measured in MPa.

Any or all the above configurable parameters, including the range values, can be changed using any host compliant to FOUNDATION fieldbus. The transmitter database is customized with specified flange type and material, O-ring and drain/vent materials and meter code option.

Custom configuration (option N6)


The following data may be specified in addition to the standard configuration parameters:

Descriptor 32 alphanumeric characters Message 32 alphanumeric characters

Date Day, month, year

Dimensions

(not for construction unless certified) – dimensions in mm. (in.)



(*) 54 (2.13) mm (in) on 1/4 – 18 NPT process flange; 51 (2.01), 54 (2.13) or 57 (2.24) mm (in) according to 1/2 – 14 NPT adapters fitting 54 (2.13) mm (in) with negative side provided with a removable filter for gauge measurement (version 266DSHxP)

Figure 1 Standard static transmitter with barrel housing - horizontal flanges

NOTE

Process connection, gasket groove and gaskets are in accordance with IEC 61518. Bolting threads for fixing adapter or other devices (i.e. manifold etc.) on process flange is 7/16 - 20 UNF.

Negative side of gauge measurement version 266DSHxP is provided with a removable filter, granting protection to the atmospheric pressure reference.





Figure 2 High static transmitter with barrel housing - horizontal flanges







Figure 3 Standard static transmitter with barrel housing - vertical flanges

...Dimensions






Figure 4 $\,$ Transmitter on bracket for vertical or horizontal 60 mm. (2 in.) pipe mounting




Figure 5 Transmitter with Kynar flanges on bracket for vertical or horizontal 60 mm. (2 in.) pipe mounting

...Dimensions




Figure 6 Transmitter with DIN aluminium housing - horizontal flanges on bracket for vertical or horizontal 60 mm. (2 in.) pipe mounting




Figure 7 Transmitter with horizontal flanges on flat bracket for vertical or horizontal 60 mm. (2 in.) pipe mounting




Figure 8 Transmitter with vertical flanges on bracket for vertical or horizontal 60 mm. (2 in.) pipe mounting





Figure 9 $\,\,$ Transmitter with barrel housing - flange mounted version

Electrical connections



HART hand-held communicator may be connected at any wiring termination point in the loop, providing the minimum resistance is 250 ohm. If this is less than 250 ohm, additional resistance should be added to allow communications. Maximum voltage drop on external remote indicator is 0.7 V DC.

Figure 11 HART Version




Figure 12 FIELDBUS Versions

...Electrical connections




Figure 13 WirelessHART version

Ordering Information

Basic ordering information for model 266DSH Differential Pressure Transmitter

Select one character or set of characters from each category and specify complete catalog number.

Refer to additional ordering information and specify one or more codes for each transmitter if additional options are required.

BASE MODEL - 1st to	6th characters			266DSH	х	Х	х	х	х х	Х
Differential Pressure	Transmitter – BASE	ACCURACY 0.06 %								
SENSOR - Span limits	- 7th character								continued	
0.05 and 1 kPa	0.5 and 10 mbar	0.2 and 4 inH2O	(Notes 17, 30) "Vx" OPTIO	N IS REQUIRED	Α			se	e next pag	ge
0.2 and 4 kPa	2 and 40 mbar	0.8 and 16 inH2O	(Notes 17, 30)		В					
0.54 and 16 kPa	5.4 and 160 mbar	2.16 and 64 inH2O	(Note 17)		Е					
0.4 and 40 kPa	4 and 400 mbar	1.6 and 160 inH2O			F					
1.6 and 160 kPa	16 and 1600 mbar	6.4 and 642 inH2O			Н					
6 and 600 kPa	0.06 and 6 bar	0.87 and 87 psi			М					
24 and 2400 kPa	0.24 and 24 bar	3.5 and 348 psi			Р					
80 and 8000 kPa	0.8 and 80 bar	11.6 and 1160 psi			Q					
160 and 16000 kPa	1.6 and 160 bar	23.2 and 2320 psi	(Note 17)		S					
Application - 8th char	acter									
Differential measur	ement at standard s	tatic pressure				S				
Differential measur	ement at high statio	pressure (REMARK)	(Note 30)			Н				
Gauge measuremen	nt					Р				
Diaphragm material /	Fill fluid (wetted pa	arts) - 9th character								
AISI 316 L ss		Silicone oil	(Note 2)	NACE			S			
Hastelloy® C-276 (c	on AISI seat)	Silicone oil	(Note 16, 17, 30)	NACE			Н			
Hastelloy® C-276		Silicone oil	(Note 30)	NACE			K			
Monel 400®		Silicone oil	(Notes 2, 17, 30)	NACE			М			
AISI 316 L ss gold p	lated	Silicone oil	(Notes 2, 17, 30)	NACE			8			
Tantalum		Silicone oil	(Notes 2, 17, 30)	NACE			Т			
AISI 316 L ss		Inert fluid - Galden	(Notes 1, 2, 17, 30)	NACE			Α			
Hastelloy® C-276		Inert fluid - Galden	(Notes 1, 2, 17, 30)	NACE			F			
Monel 400®		Inert fluid - Galden	(Notes 1, 2, 17, 30)	NACE			С			
AISI 316 L ss gold p	lated	Inert fluid - Galden	(Notes 1, 2, 17, 30)	NACE			9			
Tantalum		Inert fluid - Galden	(Notes 1, 2, 17, 30)	NACE			D			
AISI 316 L ss		Inert fluid - Halocarbon	(Notes 1, 2, 30)	NACE			L			
Hastelloy® C-276		Inert fluid - Halocarbon	(Notes 1, 2, 30)	NACE			Р			
Monel 400®		Inert fluid - Halocarbon	(Notes 1, 2, 17, 30)	NACE			4			
AISI 316 L ss gold p	lated	Inert fluid - Halocarbon	(Notes 1, 2, 17, 30)	NACE			1			
Tantalum		Inert fluid - Halocarbon	(Notes 1, 2, 17, 30)	NACE			5			

REMARK

HIGH STATIC VERSION IS NOT IN COMPLIANCE WITH ISA 12.27.01 FOR SEALING REQUIREMENTS, SPECIFICALLY FOR FM APPROVAL (Canada).

...Ordering information

... Basic ordering information for model 266DSH Differential Pressure Transmitter

Basic ORDERING INFORMATION mode	l 266DSH Diff	erential Pressure Tr	ansmitter		266DSHX)	(X X	Х	X
rocess flanges/adapters material an	nd connection	(wetted parts) - 10	th character					
AISI 316 L ss (Horizontal connection	1)	1/4 in. – 18 NPT-f dir	rect		NACE	Α		
AISI 316 L ss (Horizontal connection	1)	1/2 in. – 14 NPT-f th	rough adapter		NACE	В		
Hastelloy® C-276 (Horizontal connec	ction)	1/4 in. – 18 NPT-f dir	rect	(Notes 3, 30)	NACE	D		
Hastelloy® C-276 (Horizontal connec	ction)	1/2 in. – 14 NPT-f th	rough adapter	(Notes 3, 30)	NACE	E		
Monel 400® (Horizontal connection))	1/4 in. – 18 NPT-f dir	rect	(Notes 3, 4, 17, 30)	NACE	G		
Monel 400® (Horizontal connection))	1/2 in. – 14 NPT-f th	rough adapter	(Notes 3, 4, 17, 30)	NACE	н		
AISI 316 L ss (Vertical connection)		1/4 in. – 18 NPT-f dir	rect	(Note 17)	NACE	Q		
AISI 316 L ss (Vertical connection)		1/2 in. – 14 NPT-f th	rough adapter	(Note 17)	NACE	Т		
Hastelloy® C-276 (Vertical connection	on)	1/4 in. – 18 NPT-f dir	rect	(Notes 3, 17, 30)	NACE	М		
Hastelloy® C-276 (Vertical connection	on)	1/2 in. – 14 NPT-f th	rough adapter	(Notes 3, 17, 30)	NACE	S		
Monel 400® (Vertical connection)		1/4 in. – 18 NPT-f dir	rect	(Notes 3, 4, 17, 30)	NACE	U		
Monel 400® (Vertical connection)		1/2 in. – 14 NPT-f th	rough adapter	(Notes 3, 4, 17, 30)	NACE	V		
PVDF Kynar® insert on AISI 316 ss fl	ange side	1/4 in. – 18 NPT-f dir	rect	(Notes 5, 6, 17, 30)		Р		
PVDF Kynar® insert on AISI 316 ss fl	ange side	1/2 in. – 14 NPT-f dir	rect	(Notes 5, 6, 17, 30)		Z		
Flange mounted version (REFER TO	"F26" ACCESS	ORY CODE FOR QUO	OTE)	(Notes 2, 6, 17, 30)		R		
Bolts/Gasket (wetted parts) - 11th ch	naracter							
For standard static, high static	AISI 316 ss		Viton®	(Notes 4, 7, 27, 30)	NACE (non expo	osed)	1	
and gauge versions	AISI 316 ss		PTFE	(Notes 1, 4, 7, 27)	NACE (non expo	osed)	2	
For standard static, gauge	AISI 316 ss -	MWP = 16 MPa	Viton®	(Notes 7, 30)	NACE		3	
and flange mounted versions	AISI 316 ss -	MWP = 16 MPa	PTFE	(Notes 1, 7)	NACE		4	
	Stainless ste	eel – MWP = 42 MPa	Viton®	(Notes 7, 27, 30)	NACE		3	
For high static version	Stainless ste	eel – MWP = 42 MPa	PTFE	(Notes 1, 7, 27)	NACE		4	
For standard static, high static	Alloy steel		Viton®	(Notes 4, 7, 27, 30)	NACE		8	
and gauge versions	Alloy steel		PTFE	(Notes 1, 4, 7, 27, 30)	NACE		9	
For PVDF Kynar process connection	AISI 316 s	s spring loaded – M\	NP = 1 MPa	(Notes 8, 27, 30)	NACE		N	
Housing material and electrical conne	ection - 12th c	haracter						
Aluminium alloy (barrel version)		1/2 in. – 14 NPT				(Note 21)		Α
Aluminium alloy (barrel version)		M20 x 1.5 (CM 20)		(TO BE USED for W	relessHART)	(Note 30)		В
AISI 316 L ss (barrel version) (I2 or I	3 required)	1/2 in. – 14 NPT				(Note 21)		S
AISI 316 L ss (barrel version) (12 or 13 required)		M20 x 1.5 (CM20)		(TO BE USED for W	relessHART)	(Note 30)		Т
Aluminium alloy (DIN version)		M20 x 1.5 (CM20)		(not Ex d or XP)		(Notes 21,	30)	J
Output/Additional options - 13th cha	racter							
HART and 4 to 20 mA - Standard fur	nctionality							
HART and 4 to 20 mA - Advanced fu	nctionality (in	cludes option R1)						
PROFIBUS PA (includes option R1)								
FOUNDATION Fieldbus (includes op	tion R1)							
HART and 4 to 20 mA Safety, cert	ified to IEC 6	1508 (includes option	on R1)			(Note	30)	
WirelessHART (includes option R1)						(Notes	20. 3	0)

NOTE - Option R1 represents the external pushbuttons

${\bf Additional\ ordering\ information\ for\ model\ 266DSH\ Differential\ Pressure\ Transmitter}$

 $\label{prop:condition} \mbox{Add one or more 2-digit code(s) after the basic ordering information to select all required options.}$

Accuracy					_			
0.04 % accuracy for	applicable ranges			(Notes 7, 17, 18, 21, 27)	D2			
Orain/vent valve (mat	erial and position) (wetted part	:s)				_		
AISI 316 L ss	on process axis	(Notes 7, 9)	NACE			V1		
AISI 316 L ss	on flange side top	(Notes 7, 10, 17)	NACE			V2		
AISI 316 L ss	on flange side bottom	(Notes 7, 10, 17)	NACE			V3		
Hastelloy® C-276	on process axis	(Notes 7, 11)	NACE			V4		
Hastelloy® C-276	on flange side top	(Notes 7, 12, 17)	NACE			V5		
Hastelloy® C-276	on flange side bottom	(Notes 7, 12, 17)	NACE			V6		
Monel 400®	on process axix	(Notes 7, 13, 17)	NACE			V7		
Monel 400®	on flange side top	(Notes 7, 14, 17)	NACE			V8		
Monel 400®	on flange side bottom	(Notes 7, 14, 17)	NACE			V9		
azardous area certif	ications (see relevant paragrapl	n for complete detailed markings)				_	
ATEX Intrinsic Safet	y Ex ia			(Note 30)			E1	
ATEX Explosion Pro-	of Ex db			(Notes 15, 21, 30)			E2	
ATEX Intrinsic Safet	y Ex ic			(Notes 21, 30)			E3	
Combined ATEX, IEC	CEx, FM Approvals (USA) and FM	Approvals (Canada)		(Notes 15, 21, 30)			EN	
FM Approvals (Cana	ada) approval (XP, DIP, IS, NI, Type	e N)		(Notes 15, 21)			E4	
FM Approvals (USA)	approval (XP, DIP, IS, NI, Type N)			(Notes 15, 21)			E6	
FM Approvals (USA	and Canada) Intrinsically Safe						EA	
IECEx Intrinsic Safe	ty Ex ia			(Note 30)			E8	
IECEx Explosion Pro	oof Ex db			(Notes 15, 21, 30)			E9	
IECEx Intrinsic Safe	ty Ex ic			(Notes 21, 30)			ER	
NEPSI Intrinsic Safe	ty Ex ia			(Notes 21, 30)			EY	
NEPSI Explosion Pro	oof Ex d			(Notes 15, 21, 30)			EZ	
NEPSI Intrinsic Safe	ety Ex ic			(Notes 21, 30)			ES	
ther hazardous area	certifications (ONLY AS ALTERN	NATIVE TO BASIC CERTIFICATION	CODE Ex)					_
Technical Regulatio	ns Customs Union (EAC) Intrinsi	Safety Ex ia for Russia		(Notes 21, 30)				٧
Technical Regulatio	ns Customs Union (EAC) Explosi	on Proof Ex d for Russia		(Notes 15, 21, 30)				١
Technical Regulatio	ns Customs Union (EAC) combin	ed Ex ia and Ex d for Russia		(Notes 15, 21, 30)				٧
Technical Regulatio	ns Customs Union (EAC) Intrinsi	Safety Ex ia for Kazakhstan		(Notes 21, 30)				١
Technical Regulatio	ns Customs Union (EAC) Explosi	on Proof Ex d for Kazakhstan		(Notes 15, 21, 30)				١
Technical Regulatio	ns Customs Union (EAC) combin	ed Ex ia and Ex d for Kazakhstan		(Notes 15, 21, 30)				٧
Inmetro (Brazil) Intr	rinsic Safety Ex ia			(Notes 21, 30)				١
Inmetro (Brazil) Exp	olosion Proof Ex d			(Notes 15, 21, 30)				١
Inmetro (Brazil) Intr	rinsic Safety Ex ic			(Notes 21, 30)				١
Combined Inmetro	(Brazil) - Intrinsic Safety Ex ia, Ex	plosion Proof and Intrinsic Safety	Ex ic	(Notes 15, 21, 30)				١
Technical Regulatio	ns Customs Union (EAC) Intrinsi	Safety Ex ia for Belarus		(Notes 21, 30)				١
Technical Regulatio	ns Customs Union (EAC) Explosi	on Proof Ex d for Belarus		(Notes 15, 21, 30)				٧
Technical Regulatio	ns Customs Union (EAC) combin	ed Ex ia and Ex d for Belarus		(Notes 15, 21, 30)				٧
Kosha (Korea) Intrir	nsic Safety Ex ia IIC T6, IP67			(Notes 19, 21, 30)				٧
	osion Proof Ex d IIC T6, IP67			(Notes 15, 19, 21, 30)				٧
	(orea) - Intrinsic Safety and Explo	asion Proof		(Notes 15, 19, 21, 30)				٧

...Ordering information

$... \ Additional \ ordering \ information \ for \ model \ 266DSH \ Differential \ Pressure \ Transmitter$

		xx	XX	XX	xx	xx	XX	XX	XX	XX	
ntegral LCD											
Digital LCD integral display with integrated keypad	(Note 19)	L1									
Digital LCD integral display with TTG (Through-The-Glass) activated keypad	(Note 19)	L5									
Integrated digital LCD display (ONLY SELECTABLE WITH OUTPUT CODE 7)	(Note 25)	LS									
external non intrusive Z, S and WP pushbuttons											
Transmitters with external pushbutton (ONLY SELECTABLE WITH OUTPUT CO	DE 7)		R1								
founting bracket (shape and material)											
For pipe/wall mounting - Carbon steel (Not suitable for AISI housing)	(Note 27)			В1							
For pipe/wall mounting - AISI 316 L ss	(Note 27)			B2							
Flat type for box - AISI 316 ss	(Note 27)			В5							
urge											
Surge/Transient Protector	(Note 21)				S2						
Operating manual (multiple selection allowed)											
German (FOR HART, WirelessHART and PROFIBUS VERSIONS)						М1					
Italian (ONLY FOR HART VERSIONS)						М2					
Spanish (FOR HART, WirelessHART and FOUNDATION Fieldbus VERSIONS)						М3					
French (ONLY FOR HART VERSIONS)						M4					
English						M5					
Portuguese (ONLY FOR HART VERSIONS)						MA					
Russian (ONLY FOR HART VERSIONS)						МВ					
Plates language							_				
German							T1				
Italian							T2				
Spanish							Т3				
French							T4				
Additional tag plate								_			
Supplemental wired-on stainless steel plate								11			
Tag and certification stainless steel plates and laser printing of tag								12			
Tag, certification and supplemental wired-on stainless steel plates and laser p	orinting of tag							13			
Configuration									_		
Standard – Pressure = inH2O/ psi at 68 °F; Temperature = deg. F									N2		
Standard – Pressure = inH2O/ psi at 39.2 °F; Temperature = deg. F									N3		
Standard – Pressure = inH2O/ psi at 20 °C; Temperature = deg. C									N4		
Standard – Pressure = inH2O/ psi at 4 °C; Temperature = deg. C									N5		
Custom									N6		
Configured for HART revision 5						(Note	e 31)		NH		
Preparation procedure										_	
Oxygen service cleaning (only available with inert fill and PTFE gasket) Pmax =10 MPa for Galden, 9 MPa for Halocarbon; Tmax=60 °C/140 °F					(Not	tes 17,	30)			P1	
Certificates (multiple selection allowed)											_
nspection certificate EN 10204–3.1 of calibration (9-point)											
nspection certificate EN 10204–3.1 of the cleanliness stage					(Not	tes 27,	30)				
nspection certificate EN 10204–3.1 of helium leakage test of the sensor module	е				(N	lote 30	0)				
nspection certificate EN 10204–3.1 of the pressure test											
Certificate of compliance with the order EN 10204–2.1 of instrument design											
PMI test of wetted parts					(1)	lote 30	2)				

$... \ Additional \ ordering \ information \ for \ model \ 266DSH \ Differential \ Pressure \ Transmitter$

		XX	XX	XX	XX	XX)
Approvals							
Metrologic Pattern for Russia	(NOT APPLICABLE WITH ANY HAZARDOUS AREA CERTIFICATION) (Note 30)	Y1					
Metrologic Pattern for Kazakhstan	(NOT APPLICABLE WITH ANY HAZARDOUS AREA CERTIFICATION) (Note 30)	Y2					
Metrologic Pattern for Belarus	(NOT APPLICABLE WITH ANY HAZARDOUS AREA CERTIFICATION) (Note 30)	Y4					
Chinese pattern	(NOT APPLICABLE WITH ANY HAZARDOUS AREA CERTIFICATION) (Note 30)	Y5					
DNV GL approval	(Notes 19, 2	1)	YA				
Approval for Custody transfer (PEND	ING)		YC				
Conformity to NAMUR NE 021 (2004) (NOT APPLICABLE WITH SURGE PROTECTOR CODE "S2") (Notes 19, 21, 24,	26)	YE				
NSF/ANSI 61 Drinking Water Certifie	d		YN				
CRN (Canadian Registration Number	OF14838.5C)		YR				
Material traceability							
Inspection certificate EN 10204-3.1	of process wetted parts (not for gaskets)			Н3			
Test report EN 10204–2.2 of pressur	e bearing and process wetted parts (not for gaskets)			H4			
National radio frequency licence							
Basic countries (Europe, USA, Canad	a)				FB		
Argentina					FA		
United Arab Emirates					FG		
India					FI		
Mexico					FM		
Electrical connection plug							
One certified stainless steel plug (su	pplied loose with thread according to housing entries)					Z 1	
Accessory							_
Manifold mounting and pressure tes	t (NOT AVAILABLE WITH OXYGEN SERVICE CLEANING - PREPARATION PROCEDURI or WITH VERTICAL FLANGES WHEN SELECTED WITH BRACKET CODE Bx) (Notes			30)			

...Ordering information

Accessory ordering information model 266DSH flanged mounted version

Select one character or set of characters from each category and specify complete additional catalog number.

BASE MODEL - 1st t	o 3rd characters			F26 X	Х	Х	ر
Process connection	s of flange mounted version						
Construction - 4th o	character						
Differential	_			F			
HIGH PRESSURE SID	E - Process mounting flange rating / Size -	5th characters					
ASME Class 150		2 in.			Α		
ASME Class 150		3 in.			В		
ASME Class 300		2 in.			D		
ASME Class 300		3 in.			Е		
EN PN 16 / 40		DN 50			М		
EN PN 16		DN 80			N		
EN PN 40		DN 80			L		
HIGH PRESSURE SID	E - Mounting flange material/seat form - 6	th characters					
AISI 316 L ss	Form RF (raised face) - serrated finish		(Note 28)	NACE		D	
AISI 316 L ss	EN 1092-1 Type B1 - serrated finish		(Note 29)	NACE		L	
LOW PRESSURE SID	E - Process flanges/adapters material and o	connection (wetted par	ts) - 7th character				
AISI 216 L ss (Horizontal connection)		1/4 in. – 18 NPT-f dire	ect	NACE			ļ
AISI 316 L ss (Hor	izontal connection)	1/2 in. – 14 NPT-f thro	ough adapter	NACE			Ē

Note 2: Not available with sensor code A and B

Note 15: Not available with Housing code J

Note 16: Not available with sensor code E, F, G, H, M, P, Q, and S

Not available with high static pressure code H

Note 18: Not available with sensor code A, B, E, S

Note 19: Not available with Output code 7

Not available with Housing code A, S, J Note 20:

Note 21: Not available with Output code 9

Not available with Output code 1, 2, 3, 7, 8

Note 23: Not available with Process Flanges/Adapters material/connection code B, E, W, H, T, S, V

Note 24: Not available with Output code 2. 3

Note 25: Not available with Hazardous area certification code WM, WN, WP

Note 26:

Not available with flange mounted version - Process flanges/adapters material/connection code R

Note 28: Not available with EN mounting flange code M, N, L

Not available with ASME mounting flange code A, B, D, E Note 29:

Note 30: Not available NSF/ANSI 61 approval code YN

Note 31: Not available with Output code 2, 3, 9

Not available with AISI 316L ss or Hastelloy C-276 (on AISI seat) diaphragms code S, H, A, L

Note 4: Not available with sensor code A

Not available with Diaphragm material/Fill fluid code S, H, K, M, A, F, C, L, P, 4 Note 5:

Note 6: Not available with sensor code A, Q, S

Note 7: Not available with Process Flanges/Adapters material/connection code P, Z

Note 8: Not available with Process Flanges/Adapters material/connection code A, B, D, E, G, H, Q, T, M, S, U, V, Y, W

Not available with Process flanges/adapters material/connection code D, E, G, H, Q, T, M, S, U, V, Y, W Note 9:

Not available with Process flanges/adapters material/connection code D, E, G, H, M, S, U, V Note 10:

Note 11: Not available with Process flanges/adapters material/connection code A, B, G, H, Q, T, M, S, U, V, Y, W, R

Not available with Process flanges/adapters material/connection code A, B, G, H, Q, T, U, V, Y, W, R

Note 13: Not available with Process flanges/adapters material/connection code A, B, D, E, Q, T, M, S, U, V, Y, W, R

Not available with Process flanges/adapters material/connection code A, B, D, E, Q, T, M, S, Y, W, R Note 14:

Standard delivery items (can be differently specified by additional ordering code)

- Adapters supplied loose
- Plug on axis of horizontal connection flange or on side bottom for horizontal connection flange with MWP= 16 MPa;
 nothing for PVDF Kynar insert or for vertical connection flange (no drain/vent valves)
- General purpose (no electrical certification)
- No display, no mounting bracket, no surge protection
- Short-form operating instruction manual and labels in english (metal nameplate; self-adhesive certification and tag)
- Configuration with kPa and deg. C units
- No test, inspection or material traceability certificates

IMPORTANT REMARK FOR ALL MODELS

THE SELECTION OF SUITABLE WETTED PARTS AND FILLING FLUID FOR COMPATIBILITY WITH THE PROCESS MEDIA IS A CUSTOMER'S RESPONSIBILITY, IF NOT OTHERWISE NOTIFIED BEFORE MANUFACTURING.

NACE COMPLIANCE INFORMATION

- 1 The materials of constructions comply with metallurgical recommendations of NACE MR0175/ISO 15156 for sour oil field production environments. As specific environmental limits may apply to certain materials, please consult latest standard for further details. AISI 316/316 L, Hastelloy C-276, Monel 400 also conform to NACE MR0103 for sour refining environments.
- 2 NACE MR-01-75 addresses bolting requirements in two classes:
 - Exposed bolts: bolts directly exposed to the sour environment or buried, incapsulated or anyway not exposed to atmosphere
 - Non exposed bolts: the bolting must not be directly exposed to sour environments and must be directly exposed to
 the atmosphere at all times.

266DSH bolting identified by "NACE (non exposed)" are in compliance with requirements of NACE MR0103 when considered "non exposed bolting".

266DSH bolting identified by "NACE" are in compliance with requirements of NACE MR0175 when considered "exposed bolting".

[®] Hastelloy is a registered trademark of Haynes International

[®] Monel and Inconel are registered trademarks of Special Metals Corporation

[®] Galden is a registered trademark of Solvay Group

[®] Halocarbon is a registered trademark of Halocarbon Products Co.

 $^{^{\}rm @}$ HART and WirelessHART are registered trademarks of HART Communication Foundation

[®] PROFIBUS is a registered trademark of Profibus International

 $^{^{\}text{\tiny{TM}}}$ FOUNDATION Fieldbus is a trademark of Fieldbus Foundation



ABB Ltd.

Measurement & Analytics

Howard Road St. Neots Cambridgeshire PE19 8EU UK

Tel: +44 (0)1480 475321 Fax: +44 (0)1480 217948

ABB Inc.

Measurement & Analytics

125 E. County Line Road Warminster PA 18974 USA

Tel: +1 215 674 6000 Fax: +1 215 674 7183

abb.com/measurement

ABB S.p.A.

Measurement & Analytics

Via Luigi Vaccani 4 22016 Tremezzina (CO) Italy

Tel: +39 0344 58111

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail.

ABB does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB.


DS/266DSH-EN Rev. M 12.2018

Three-Valve Manifolds

.187" **ORIFICE**

PROCESS





MATERIALS OF CONSTRUCTION

SEAT	MAX Cv RATINGS		
Hard Ball	.53		
Soft Cone	.83		
Approx. Manifold Weight:	4.2 lbs each [M-500 / 501] 5.2 lbs each [M-650 / 651] 5.7 lbs each [M-750 / 751]		
INSTRUMENT			
A	A		

INSTRUMENT	
VENT/TEST	VENT/TEST
PROCESS	


CARBON STEEL	A105 CARBON STEEL	316 SS	MONEL*	HASTELLOY-C®
ASTM A108-1215	ASTM A105 CF	ASTM A479-316	ASTM B164-N04405 or ASTM B164-N04400	ASTM B575-N10276 or ASTM A494 CW-12MW
ASTM A108-1215	ASTM A479-316	ASTM A479-316	ASTM B165-N04405	ASTM B574-N10276
ASTM A582-303	ASTM A479-316	ASTM A479-316	ASTM B164-N04405	ASTM B574-N10276
ASTM A479-316	ASTM A479-316	ASTM A479-316	ASTM B164-N04405	ASTM B574-N10276
ASTM A108	ASTM A108	ASTM A582 (18-8)	ASTM A582 (18-8)	ASTM A582 (18-8)
ASTM A108	ASTM F593 (18.8)	ASTM A182-F (18-8)	ASTM B164-N04405	ASTM B574-N10276
ASTM A449-TYPE 1	ASTM A449-TYPE 1	ASTM A449-TYPE 1	ASTM F593 (18-8)	ASTM F593 (18-8)
	ASTM A108-1215 ASTM A108-1215 ASTM A582-303 ASTM A479-316 ASTM A108 ASTM A108	ASTM A108-1215 ASTM A105 CF ASTM A108-1215 ASTM A479-316 ASTM A582-303 ASTM A479-316 ASTM A479-316 ASTM A479-316 ASTM A108 ASTM A108 ASTM A108 ASTM A108	ASTM A108-1215 ASTM A105 CF ASTM A479-316 ASTM A108-1215 ASTM A479-316 ASTM A479-316 ASTM A582-303 ASTM A479-316 ASTM A479-316 ASTM A479-316 ASTM A479-316 ASTM A479-316 ASTM A108 ASTM A108 ASTM A582 (18-8) ASTM A108 ASTM A108 ASTM A182-F (18-8)	ASTM A108-1215 ASTM A479-316 ASTM A479-316 ASTM B164-N04405 or ASTM A108-1215 ASTM A479-316 ASTM A479-316 ASTM A582-303 ASTM A479-316 ASTM A582 (18-8) ASTM A108 ASTM A108 ASTM A582 (18-8) ASTM A582 (18-8) ASTM A108 A

- · Carbon Steel Manifolds are Zinc Cobalt Plated with Dichromate Dip
- 316 SS Manifolds Meet NACE MR0175 Requirements (Latest Revision)
- 100% Pressure Tested
- · Carbon Steel Weld End Connection Bodies are AISI 1018

Three-Valve Manifolds

.187" ORIFICE


ORDERING INFORMATION



OPTIONS

- Versa-Mount Brackets
- Bonnet Handle Lock-Out
- **Bonnet Lock Plates**
- Steam Trace Block
- Integral Tube Fitting Connections






PRESSURE & TEMPERATURE

BODY MATERIAL	HARD SEAT Teflon Pressure-Core CODE T	HARD SEAT Teflon Pressure-Core CODE K	HARD SEAT Grafoil
Carbon Steel Code C	10,000 PSI @ 200° F 8,000 PSI @ 450° F	6,000 PSI @ 400° F	Not Available.
A105 Carbon	10,000 PSI @ 200° F	Not Available	6,000 PSI @ 200° F
Steel Code P	8,000 PSI @ 450° F		1,500 PSI @ 800° F
316 SS Code S	10,000 PSI @ 200° F 8,000 PSI @ 450° F	6,000 PSI @ 400° F	6,000 PSI @ 200° F 1,500 PSI @ 1,000° F
See Page 5:	Chart D	Chart D Chart F	
BODY MATERIAL	SOFT SEAT (Delrin) Teflon Pressure-Core CODE T	Teflon Pre	EAT (Peek) essure-Core DE T
Carbon Steel Code C	6,000 PSI @ 200° F	10,000 PSI @ 200° F 3,000 PSI @ 400° F	
316 SS Code S	6,000 PSI @ 200° F	10,000 PSI @ 200° F 3.000 PSI @ 400° F	
See Page 5:	Chart A	Chart B	

CODE	OPTION DESCRIPTION			
AU7	½" Integral Tube Fitting - Parker® A-LOK Dual Ferrules (Process Ports)			
AV7	1/2" Integral Tube Fitting - Swagelok® Dual Ferrules (Process Ports)			
GA	Anti-Tamper Bonnet (All Positions)			
GC	Anti-Tamper Bonnet (Isolate Valve(s) Only)			
GD	Anti-Tamper Bonnet (Equalizer Valve(s) Only)			
GJ	Bonnet Lock-Out (All Positions - Lock Not Provided)			
GK	Bonnet Lock-Out (Isolate Valve(s) Only - Lock Not Provided)			
GL	Bonnet Lock-Out (Equalizer Valve(s) Only - Lock Not Provided)			
ME	Slotted Instrument Flange Using Bolts over 3"			
MH	Viton® O-Ring Flange Seals			
MU	Dielectric Isolation (Flange Manifolds Only)			
M7	Required Slotting for Rosemount® 1151 Transmitters Series 6 & Above (Flange Manifolds Only)			
PB	(2) ¼" Constant Purge Ports (Bottom) See pg. 61 for port locations.			
PT	(2) ¼" Constant Purge Ports (Top) See pg. 61 for port locations.			
P1	Purge or Test Connections			
TC	Steam Trace Block - Carbon Steel			
TH	Hydrostatic Testing			
TS	Steam Trace Block - 316 SS			
VA	Bracket Spacer for Flange to Flange Manifolds			
VC	CS Versa-Mount Bracket			
VS	316 SS Versa-Mount Bracket			
VCH	CS Heavy-Duty Versa-Mount Bracket			
VSH	316 SS Heavy-Duty Versa-Mount Bracket			
W	Safety Bonnet Lock Plate			
WA	CS 2-4" Bolts for Rosemount® 3051C, 3095, or 2024 with			
WAW3	300 SS Coplanar™ (Flange Manifolds Only)			
WAW9	316 SS Copialial (Flange Manifolds Only)			
WK	Paper Tag			
W1	316 SS Tag (20 Characters ~ See page 61)			
W3	300 SS Standard Length Flange Bolts (CS Standard)			
W9	316 SS Standard Length Flange Bolts (CS Standard)			
XL	Clean for Critical Service (Oxygen or Chlorine)			
Х3	(2) ¼" Test Ports on Instrument Flange (Flange Manifolds Only) See pg. 61 for port locations.			



SHEET 17 OF 66 SHEETS

IFB Job No. 02-14, Addendum No. 3 Material Substitution Request No. 3 (DENIED-6 pages)



ARCHITECTURAL SPECIALTIES * 2538 Alaula Way, Honolulu, HI 96822

March 7, 2023

Procurement Officer Jason Kagimoto Engineering Division Department of Water, County of Kaua'i 4398 Pua Loke St. Suite 1600 Lihue, HI 96766

> SUBJECT: SUBSTITUTION REQUEST PROJECT TITLE: WK-08, KAPA'A HOMESTEADS 325' TANKS,

TWO 0.5 MG TANKS, PACKAGE B - TANKS PACKAGE

KAPA'A, KAUA'I, HAWAI'I

In accordance with the GENERAL PROVISIONS for construction, enclosed are sets of technical brochures and statement of variances for your review and approval for the item(s) shown below:

SECTION/	SPECIFIED BRAND(S)	SUBSTITUTE OR	VARIANT
ITEM		ALTERNATE BRAND	FEATURES
SP-6/ Aluminum Horizontal Access Doors	Bilco	Babcock-Davis	None

I certify that the substitution request of the above item(s) has no other variant features.

President

Tel: (808) 773-7478 * e-mail: <u>DivisionXOffice@divxhi.com</u>

SECTION SP-6 - ALUMINUM HORIZONTAL ACCESS DOORS

6.01 GENERAL: Work includes furnishing and installing factory-fabricated vault access doors.

6.02 REFERENCES:

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by the basic designation only. Where a referenced document contains references to other standards, those documents are included as references under this section as if referenced directly. In case of conflict between the requirements of this specification and those of the listed documents, the requirements of this specification shall prevail.

Unless otherwise specified, references to documents shall mean the documents in effect at the time of Advertisement for Invitation for Bids (IFB). If referenced documents have been discontinued by the issuing organization, references to those documents shall mean the replacement documents issued or otherwise identified by that organization or, if there are no replacement documents, the last version of the document before it was discontinued. Where document dates are given in the following listing, references to those documents shall mean the specific document version associated with that date, regardless of whether the document has been superseded by a version with a later date, discontinued, or replaced.

- ASTM A 36-93a: Standard Specification for Structural Steel.
- 6.03 <u>SUBMITTALS</u>: The Contractor shall submit manufacturer's product data for all materials in this specification. Shop drawings must show profiles, accessories, location and dimensions. Manufacturer to provide samples upon request; sized to represent material adequately. Vault access door manufacturer shall provide Manufacturer's Warranty.
- 6.04 PRODUCT HANDLING: All materials shall be delivered in manufacturer's original packaging. Materials must be stored in a dry, protected, well-vented inspect product upon receipt and report damaged material immediately to the delivery carrier and note such damage on the carrier's freight bill of lading.
- 6.05 JOB CONDITIONS: The Contractor shall verify that other trades with related work are complete before installing vault access door(s). Mounting surfaces shall be straight and secure; substrates shall be of proper width. Refer to construction documents, shop drawings, and manufacturer's installation instructions. Contractor shall observe all appropriate OSHA safety guidelines for this work.
- 6.06 WARRANTY / GUARANTEE: Manufacturer's standard warranty: Materials shall be free of defects in material and workmanship for a period of twenty-five (25) years from the date of purchase. Should a part fail to function in normal use within this period, manufacturer shall furnish a new part at no charge. Electric motors, special finishes, and other special equipment shall be warranted separately by the manufacturers of those products.
- 6.07 MANUFACTURER: Aluminum horizontal access doors shall be as manufactured by The Bilco Company or approved equal.
- 6.08 ACCESS DOOR:

A. The Contractor shall furnish and install where indicated on the plans, vault access doors. Type, size, and hinge side shall be as indicated on the plans.

B. Performance characteristics:

- (1) Covers: Shall be reinforced to support AASHTO H-20 wheel load with a maximum deflection of 1/150th of the span. Manufacturer to provide structural calculations stamped by a registered professional engineer licensed in the State of Hawai'i.
- (2) Operation of the covers shall be smooth and easy with controlled operation throughout the entire arc of opening and closing.
- (3) Operation of the covers shall not be affected by temperature.
- (4) Entire door, including all hardware components, shall be highly corrosion resistant.
- C. Covers: Shall be 1/4" (6.3 mm) aluminum diamond pattern.
- D. Frame: Channel frame shall be ¼" (6.3 mm) extruded aluminum with bend down anchor tabs around the perimeter. A continuous EPDM gasket shall be mechanically attached to the aluminum frame to create a barrier around the entire perimeter of the cover and significantly reduce the amount of dirt and debris that may enter the channel frame.
- E. Hinges: Shall be specifically designed for horizontal installation and shall be through bolted to the cover with tamperproof Type 316 stainless steel lock bolts and shall be through bolted to the frame with Type 316 stainless steel bolts and locknuts.
- F. Drain Coupling: Provide a 1-1/2" (38 mm) drain coupling located in the right front corner of the channel frame, unless otherwise indicated on the plans.
 - Lifting Mechanisms: Manufacturer shall provide the required number and size of compression spring operators <u>enclosed</u> in telescopic tubes to provide, smooth, easy, and controlled cover operation throughout the entire arc of opening and to act as a check in retarding downward motion of the cover when closing. The upper tube shall be the outer tube to prevent accumulation of moisture, grit, and debris inside the lower tube assembly. The lower tube shall interlock with a flanged support shoe fastened to a formed ½" gusset support plate.
- G. Turn/Lift Handle: A removable exterior turn/lift handle with a spring-loaded ball detent shall be provided to open the covers and the latch release shall be protected by a flush, gasketed, removable screw plug.

H. Hardware:

- (1) Hinges: Heavy forged aluminum hinges, each having a minimum ¼" (6.3 mm) diameter Type 316 stainless steel pin, shall be provided and shall pivot so the cover does not protrude into the channel frame.
- (2) Covers shall be equipped with a hold open arm that automatically locks the covers in the open position.


Job No. 02-14 WK-08, KAPA'A HOMESTEADS 325' TANKS, TWO 0.5 MG TANKS, PACKAGE B – TANKS PACKAGE, KAPA'A


- (3) Covers shall be fitted with a required number and size of compression spring operators. Springs shall have an electrocoated acrylic finish. Spring tubes shall be constructed of a reinforced nylon 6/6-based engineered composite material.
- (4) A Type 316 stainless steel snap lock with fixed handle shall be mounted on the underside of the cover.
- (5) Hardware: Shall be Type 316 stainless steel.
- Finishes: Factory finish shall be mill finish aluminum with bituminous coating applied to the exterior of the frame.
- J. Spare Keys: Contractor shall furnish three (3) door keys for each door to the Department of Water at the completion of the project.
- 6.09 <u>INSPECTION</u>: Verify that the vault access door installation will not disrupt other trades. Verify that the substrate is dry, clean, and free of foreign matter. Report and correct defects prior to any installation.


6.10 INSTALLATION:

- Submit shop drawing for review and approval before fabrication.
- B. The Contractor shall check as-built conditions and verify the manufacturer's vault access door details for accuracy to fit the application prior to fabrication. The Contractor shall comply with the vault access door manufacturer's installation instructions.
- C. The Contractor shall furnish mechanical fasteners consistent with the vault access door manufacturer's instructions.
- 6.11 <u>PAYMENT:</u> Payment for ALUMINUM HORIZONTAL ACCESS DOORS shall not be made separately; the compensation shall be considered incidental to the various items of the Offer for which it is a part of.

END OF SECTION







LENGTH

SPECIFICATIONS:

(1) DOOR: ALUMINUM 1/4" DIAMOND PLATE, MILL FINISH WITH AN H20 LOAD RATING FOR INFREQUENT LOW SPEED TRAFFIC WITH A MAX SPAN DEFLECTION OF L/150

 $\langle \overline{2} \rangle$ FRAME:

ALUMINUM, 1/4" EXTRUSION, GRAY PRIMER FINISH ON EXTERIOR SURFACES THAT COME INTO CONTACT WITH CONCRETE

- (3) HINGES: TYPE 316 STAINLESS STEEL
- ⟨4⟩ SLAM LATCH:

TYPE 316 STAINLESS STEEL WITH INSIDE LEVER HANDLE AND

OUTSIDE REMOVABLE HANDLE (5) COUNTER-BALANCE SPRING:

- ENCLOSED, TYPE 17-7 SST SPRING
- (6) HOLD-OPEN ARM:

TYPE 316 STAINLESS STEEL WITH RED VINYL GRIP HANDLE PROPRIETARY AND CONFIDENTIAL: THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BABCOCK-DAVIS. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BABCOCK-DAVIS IS PROHIBITED.

(7) FLUSH LIFT HANDLE: TYPE 316 STAINLESS STEEL

(8) DRAINAGE COUPLING: 1-1/2"

(9) FLUSH TYPE PLUG SEAL: TYPE 316 STAINLESS STEEL

(10) GASKET: EPDM

FLOOR DOOR SIZE:


ARCHITECT CONTRACTOR: QTY: PART#: TITLE: **babcock**davis® FD, Drainable H20, Sngl Dr, Alum, 1/4" Dmd, Mill, Gutter Frame, Gray Primer, Cast-In 9300 73rd Avenue North, Brooklyn Park, MN 55428 REV NAME DATE SIZE DWG. NO. Babcock FD BFDDHA_X_SFL ShpDr Α DRAWN BES 4/11/19


RELEASED BES SHEET 1 OF 2 4/11/19 WEIGHT:


2

PROJECT:









SLAM LATCH DETAIL

babcock davis [®]	
9300 73rd Avenue North Brooklyn Park, MN 55428	
	т

TITLE: FD, Drainable H20, Sngl Dr, Alum, 1/4" Dmd, Mill, Gutter Frame, Gray Primer, Cast-In

REV SIZE DWG. NO. Babcock FD BFDDHA_X_SFL ShpDr DRAWN Α BES 4/11/19 RELEASED BES 4/11/19 WEIGHT: SHEET 2 OF 2

В