

# ADDENDUM NO. 2

COUNTY OF KAUA'I  
DEPARTMENT OF WATER

PLANS, PROPOSAL, SPECIFICATIONS  
CONTRACT AND BOND  
FOR

**JOB NO. 23-09**  
**PAUA VALLEY WELL MOTOR CONTROL CENTER REPLACEMENT**  
**KAUA'I, HAWAI'I**

## NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

### Item 1

Department's Responses to Questions/Comments/Material Substitutions.

### End of Addendum No. 2

If there are any questions, please call Ryan Smith at (808) 245-5436.



\_\_\_\_\_  
Joseph E. "Joe" Tait  
Manager and Chief Engineer  
November 2, 2023

## ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 2

Receipt Acknowledged:

\_\_\_\_\_  
Organization

\_\_\_\_\_  
Received by

\_\_\_\_\_  
Date

\_\_\_\_\_  
Title

(Please sign and return this acknowledgement.)

## ADDENDUM NO. 2

**QUESTION 1:** Good morning. I would like to verify the following;

1. Will the facility needs to be operational during construction?
2. Will an Archeologist &/or a Cultural Monitor be needed for this project?

Thank you very much.

**ANSWER 1:** 1. No, the facility does not need to be operational during construction.

2. No, the project will not require Archeological or Cultural monitoring.

**QUESTION 2:** 1. Please confirm that the new submersible deep well pump shown on the New Electrical One-Line Diagram on sheet E31 is not part of this RFQ.

2. In reference to sheet E31, New Electrical One-Line Diagram, where is the existing JB for the booster pump located?

**ANSWER 2:** 1. Confirmed, not part of this IFB.

2. Existing JB for Booster Pump is located on the wall next to the Booster Pump inside the MCC Room.