

ADDENDUM NO. 2

COUNTY OF KAUA'I
DEPARTMENT OF WATER

PLANS, PROPOSAL, SPECIFICATIONS
CONTRACT AND BOND
FOR

**JOB NO. 24-10
PIWAI WELL NO. 3 REPAIR
KAUA'I, HAWAII**

NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

Item 1

DOW Response to Questions/Comments/Material Substitution Requests.

End of Addendum No. 2

If there are any questions, please contact Ryan Smith by email at rsmith@kauaiwater.org.



Joseph E. "Joe" Tait
Manager and Chief Engineer
September 21, 2023

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 2

Receipt Acknowledged:

Organization

Received by

Date

Title

(Please sign and return this acknowledgement.)

ADDENDUM NO. 2

QUESTION 1: I see that the pre bid meeting attendees were all employees from KDOW. I didn't see any contractors listed. Did any attend? Will you have another scheduled?

ANSWER 1: The personnel that attended the pre-bid are noted on the sheet. There will not be another pre-bid meeting.

QUESTION 2: Please confirm if a new motor is to provided. Offer schedule states new motor. 2.2, F Description of existing equipment, page 73, Motor (save for re-installation)

ANSWER 2: Confirmed, a new motor is to be supplied to replace the existing motor per the offer schedule. Section 2.2, F Description of existing equipment, page 73, Motor (save for re-installation) is a typo and should not have the wording in parentheses.