

ADDENDUM NO. 2

COUNTY OF KAUA'I
DEPARTMENT OF WATER

PLANS, PROPOSAL, SPECIFICATIONS
CONTRACT AND BOND
FOR

**JOB NO. 24-15,
LĪHU'E ADMINISTRATIVE BUILDING FENCING
KAUA'I, HAWAI'I**

NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

Item 1

Department's Responses to Questions/Comments/Material Substitutions.

End of Addendum No. 2

Please submit questions for this solicitation at www.publicpurchase.com .



Joseph E. "Joe" Tait
Manager and Chief Engineer
Chief Procurement Officer
November 1, 2024

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 2

Receipt Acknowledged:

Organization

Received by

Date

Title

(ADDENDUMS MUST BE ACKNOWLEDGED AND INCLUDED WITH OFFER)

ADDENDUM NO. 2

Question 1:

Will the chain link material be galvanized steel as described in SP-3, Part 2, 2.1.1 or aluminum as shown on detail 1, sheet C-500?

Response:

Thank you for your question. The chain link material is galvanized steel.